
Lowcountry Regional Water System

Cross Connection Control Program



SCDHEC Water Systems:

#2510004 (Brunson)

#2510009 (Gifford)

#2510001 (Hampton)

#2510005 (Varnville)

#2510006 (Yemassee)

#2570908 (Yemassee - Industrial Park)

CREATED: AUGUST 2013

UPDATED: MARCH 2016

INTRODUCTION

Under the Safe Drinking Water Act (SDWA), a water supplier is responsible for preventing polluted or contaminated water or other substances from entering a public drinking water system. The control of interconnections (cross connections) between drinking water systems (potable) and other water systems of questionable quality (non-potable) is an integral component of providing a safe public drinking water distribution system.

The State Primary Drinking Water Regulations promulgated pursuant to Section 44-55-30 through 44-55-60 of the 1976 South Carolina Code of Laws, R-61-58.7F. Cross-Connection Control mandates that all public water systems shall initiate and maintain a program for the detection, elimination and prevention of cross connections. Pursuant to these regulations, the program shall consist of (1) locating and eliminating unprotected cross connections and (2) maintaining records pertaining to the location of existing backflow prevention assemblies, type and size of each assembly and annual test results.

To comply with these requirements, LRWS has established a Cross Connection Control Program as outlined in this document, as follows:

Section 1 – Cross Connection Control Program Requirements

Section 2 – SC DHEC Approved Backflow Prevention Assemblies

Section 3 – Testing Requirements & List of Certified Testers

Section 4 – Testing Notification Letter and Report Form

Section 5 – Inventory of LRWS Testable Devices & Test Results for Backflow Prevention Devices

Section 6 – Residential Lawn Irrigation Systems

Section 7 – State Primary Drinking Water Regulation for Cross Connection Control

SECTION 1: CROSS CONNECTION CONTROL REQUIREMENTS

1. Employees of LRWS will not install, permit to be installed or maintain any cross connection between the public water system and any other non-potable source unless an approved backflow prevention device is installed between the water system and the source contamination.
 - a. LRWS will conduct on-site evaluation of all new construction for possible sources of cross connections.
 - b. During normal operations, LRWS field staff will inspect existing connections to determine where cross connection hazards may exist (such as private wells, irrigation systems, etc).
 - c. LRWS will conduct annual inspections of all high hazard facilities for potential cross connections.
 - d. Any cross connection that is identified will be reported to the Distribution Supervisor.
 - e. Any cross connection that is identified that poses an immediate hazard to public health will be disconnected from the water system until proper protection has been installed and tested.
2. The type of protective device required depends upon the degree of hazard that exists as follows:
 - a. A connection between LRWS and a service that is connected to any water or material that is dangerous to health will be categorized as High Hazard and will be protected by an air gap separation or an approved reduced pressure principle backflow prevention assembly.
 - i. A reduced pressure principle backflow assembly will not be installed in any location subject to possible flooding.
 - b. A connection between LRWS and a service that is connected to any water or material that would be objectionable based upon LRWS standards but not hazardous to health will be categorized as Low Hazard and will be protected by an approved double check valve or approved pressure vacuum breaker assembly.
 - c. A connection between LRWS and a fire sprinkler system, except those that are highly hazardous, will be protected by an approved double check valve assembly.
 - i. High hazard fire sprinkler systems are systems that may include hazardous materials such as antifreeze or foams, or are tied into ponds, lakes or any other water source other than an approved water supply.
 - ii. High hazard fire sprinkler systems will be protected by an air gap separation or an approved reduced pressure principle backflow prevention assembly.
 - d. A connection between LRWS and a low hazard residential irrigation system (with no chemical addition) will be protected by a residential dual check which will be installed as part of the meter assembly.

SECTION 2: APPROVED BACKFLOW PREVENTION ASSEMBLIES:

Only backflow prevention assemblies approved by SC DHEC are permitted in the LRWS water system. SC DHEC prepares and publishes a list of approved devices on an annual basis. Following is a current list of approved devices.

February 26, 2014

**NOTICE OF APPROVED BACKFLOW
PREVENTION ASSEMBLIES FOR SOUTH CAROLINA**

Enclosed is the revised list of approved backflow prevention assemblies and a list of backflow equipment representatives.

The following should be considered before selecting a particular assembly:

1. All local plumbing laws and regulations must be adhered to.
2. Manufacturer's installation instructions shall be strictly adhered to.
3. Reduced pressure principle assemblies shall be installed so that the relief port will never become submerged. This prohibits installation in a pit that cannot be drained by gravity to the surface of the ground. Also, RPPA are not acceptable for the vertical orientation unless approved by the University of Southern California's Foundation for Cross Connection Control & Hydraulic Research.
4. The operating performance of these assemblies varies among manufacturers; therefore, it suggested that local water authorities be contacted to assist in selecting an assembly which is best suited for that particular system.
5. The South Carolina Department of Health and Environmental Control reserves the right to add or to remove from the approved list any reduced pressure principle assembly, pressure vacuum breaker, or double check valve assembly.
6. It is a requirement that backflow prevention assemblies be tested immediately after installation and at least once a year thereafter. If a serious defect is discovered at the time of the first (immediate inspection after installation) inspection or after any subsequent inspections, it is requested that the Department of Health and Environmental Control be notified so prompt action can be taken to review the approved status of the assembly.
7. By-pass piping is not permitted unless the by-pass piping is equipped with an approved backflow prevention assembly similar to the main line assembly. In many instances it will be desirable, or necessary to install two approved backflow prevention assemblies in order that water service will not be interrupted during the testing or repair of the assembly.


8. Some manufacturers market, as non-standard equipment, assemblies capable of withstanding elevated temperatures. The high temperature assemblies should be ordered from the manufacturer to include documentation certifying their ability to withstand high temperatures.

9. Any reduced pressure principle assembly, pressure vacuum breaker, or double check valve assembly on this list of approved assemblies must be equipped with either resilient seated ball valves or resilient wedged gate valves. Butterfly valves are acceptable on backflow assemblies as long they are approved by the University of Southern California's Foundation for Cross Connection Control & Hydraulic Research.


10. If a manufacturer markets a prefabricate "manifold" series it will be approved as long as both of the assemblies in the manifold are from the approved list.

11. If a manufacturer markets a double detector check valve assembly or a reduced pressure principle detector assembly it will be approved as long as both assemblies are from the approved list. Both assemblies (main line assembly and by-pass assembly) must be assembled by the manufacturer and shipped as a complete assembly. Any alterations of this assembly in the field must meet manufacturer's specifications and/or the USCFCCC&HR.

All assemblies on this approval list must be equipped with resilient seated ball valves or resilient wedged gate valves. Butterfly valves are acceptable on backflow assemblies as long as they are approved by (USCFCCC&HR).



Double Check Assembly
Outdoor Installation -OS&Y Gates



Reduced Pressure Assembly
Outdoor Installation -OS&Y Gates

SCDHEC

LIST OF APPROVED BACKFLOW PREVENTION ASSEMBLIES

DOUBLE CHECK VALVE ASSEMBLIES

DCVA's are approved for use when protecting the potable water system from backflow when a low degree of hazard is involved. A low degree of hazard is one which may cause an actual or potential threat to the physical properties of the water system or the potability of the public or consumer's potable water system. However, a low degree of hazard would not constitute a health or system hazard. The maximum degree or intensity of pollution to which the potable water system could be degraded under this definition would cause a nuisance or be aesthetically objectionable.

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Ames	2000B	½", ¾", 1", 1¼", 1½", 2"
	2000 (Epoxy)	4", 6", 8", 10"
	2000SS	¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10", 12"
	2000SE	2½", 6", 8"
	2001SS	3", 4", 6", 8"
	2001SSN	3", 4", 6", 8"
	2001SSZ	3", 4", 6", 8"
	Colt200	2½", 3", 4", 6", 8", 10"
	Colt200A	2½", 3", 4", 6", 8", 10"
	Colt200N	2½", 3", 4", 6", 8", 10"
	Colt200Z	2½", 3", 4", 6", 8", 10"
	Maxim200	2½", 3", 4", 6", 8"
	Maxim200A	2½", 3", 4", 6", 8"
	Maxim200N	2½", 3", 4", 6", 8"
	Maxim200Z	2½", 3", 4", 6", 8"
Beeco-Hersey	#2	3", 4", 6", 8", 10"
	FDC	¾", 1", 1½", 2"
	HDC	¾", 1", 1½", 2"
Buckner	24100 thru 24104	¾", 1", 1¼", 1½", 2"
Cash Acme	DC 100	¾", 1", 1½", 2"
	DC 500	¾", 1"
Cla-Val	D2	¾", 1", 1¼", 1½"
	D4	2", 2½", 3", 4", 6", 8", 10""
	DC6LB	¾", 1", 1½", 2"
	DC6LW	¾", 1", 1½", 2"
	DC7LW	2½", 3", 4", 6", 8", 10"

DOUBLE CHECK VALVE ASSEMBLIES CONTINUED:

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Cla-Val	DC7LY	2½", 3", 4", 6", 8", 10"
	DC8LW	2½", 3", 4", 6", 8", 10"
	DC8LY	4", 6", 8"
	DC8NW	2½", 3", 4", 6", 8", 10"
	DC8NY	2½", 3", 4", 6", 8"
	DC8VW	2½", 3", 4", 6"
	DC8VY	2½", 3", 4", 6"
Conbraco/Apollo	4S	½"
	40-100 Series	½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	40-104 A2T thru	
	40-108 A2T	¾", 1", 1¼", 1½", 2"
	4S-100 Series	2½", 3", 4", 6", 8", 10"
	4SG-100	2½", 3", 4", 6", 8"
	DC4A	½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8"
	DCLF4A	½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8"
	DC4AN	2½", 3", 4", 6", 8"
	DCLF4AN	2½", 3", 4", 6", 8"
Febco	805	¾", 1", 1½", 2", 3", 4",
	805Y	¾", 1", 1½", 2", 2½", 3", 4", 6", 8", 10"
	805YB & YR	¾", 1"
	805YD	2½", 3", 4", 6", 8", 10"
	850	¾", 1", 1½", 2", 2½", 3", 4", 6", 8"
	LF850	½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	LF850U	½", ¾", 1", 1¼", 1½", 2"
	870	2½", 3", 4", 6", 8", 10"
	870V	2½", 3", 4", 6", 8", 10"
	LF870V	2½", 3", 4", 6", 8"
	830	4", 6", 8"
	830H	4", 6"
Flomatic	DCV	¾", 1", 1½", 2", 2½", 3", 4", 6", 8"
	DCVE	¾", 1", 1½", 2"

DOUBLE CHECK VALVE ASSEMBLIES CONTINUED:

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Watts	709QT	$\frac{3}{4}''$, 1", $1\frac{1}{2}''$, 2", $2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	709	$2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	719QT	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2"
	007	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2", 3"
	007M1&M2QT	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2"
	007M3QT	$\frac{3}{4}''$
	770	4", 6", 8"
	772	4", 6", 8", 10"
	774	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2", $2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	774X	$2\frac{1}{2}''$, 6", 8"
Wilkins	775QT	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2"
	775	3", 4", 6", 8"
	N775	3", 4", 6", 8"
	757A	$2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	757N	$2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	767A	$2\frac{1}{2}''$, 3", 4", 6", 8"
	767N	$2\frac{1}{2}''$, 3", 4"
	350	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2", $2\frac{1}{2}''$, 3", 4", 6", 8", 10", 12"
	350A	$2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	350AR & ARXL	$2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	350AST	$2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	350 ASTR	$2\frac{1}{2}''$, 3", 4", 6"
	350XL	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2", $2\frac{1}{2}''$, 3", 4", 6", 8", 10", 12"
	350AXL	$2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	450 & XL	$2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	950	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2", $2\frac{1}{2}''$, 3", 4", 6", 8", 10"
	950A	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2"
	950XLT	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2"
	950XLTU	$\frac{3}{4}''$, 1"
	950XL	$\frac{3}{4}''$, 1", $1\frac{1}{4}''$, $1\frac{1}{2}''$, 2"
	950XLD	$\frac{3}{4}''$, 2"
	950XLU	$\frac{3}{4}''$, 1", $1\frac{1}{2}''$, 2"
	950XLTDA & XLTDABF	2"
	950XLT2	$\frac{3}{4}''$, 1", $1\frac{1}{2}''$, 2"
	950XLT2U	$\frac{3}{4}''$

The following assemblies are Double DETECTOR Check Valve Assemblies and Reduced Pressure Principle DETECTOR Assemblies. These assemblies are made up from DCVA's and RPPA's which are approved elsewhere on this list. These assemblies are designed for FIRE LINE use. If a Double Detector Check Valve Assembly or Reduced Pressure Principle Detector Assembly is prescribed, it should be done with an understanding that its meter will have to be read periodically in order to be of any value. Don't forget that when the annual testing is done, both of these assemblies are required to be tested (mainline dcva and by-pass dcva). Lastly, both assemblies (main line assembly and by-pass assembly) must be assembled by the manufacturer and shipped as a complete assembly. Any alterations of this assembly in the field must meet manufacturer's specifications and/or the USCFCCC&HR.

DOUBLE DETECTOR CHECK VALVE ASSEMBLIES ARE:

AMES - 3000SS, 3000SE, (3001SS & 3001SSN & 3001SSZ 3"-8"),
(Colt300 2½"-10") (Colt300A 2½"-10"), (Colt300N 2½"-10"),
(Maxim300 2½"-8"), (Maxim300N 2½"-8")
BEECO-HERSEY - DDCII
CLAVAL - DD7LY, DD8LY, DD8NY
CONBRACO/APOLLO - 40-600, 40-60A, 40-60C, 40-60E, 40-60G,
(4SG-600 2½"-8"), DA4S 10", (4A-600 2½"-8"), (4AN-600 2½"-8")
FEBCO - 806YD, 856, (856ST 2½"-10"), 876, 876V, (876VST 2½"-8"),
(831 4"-8"), (831H 4"-6")
WATTS - 007DCDA, 709DCDA, 770DCDA, 772DCDA, 774DCDA, and
774XDCDA, (775DCDA & N775DCDA 2½"-10"), (757DCDA 2½"-10")
(757NDCDA 2½"-10"), (767NDCDA 2½"-4")
WILKINS - (950DA 2½"-10"), (350DA 2½"-12"), (350ADA &
350ADAR 2 ½"-10"), (350ASTDA 2 ½"-10"), (450DA 4"-10")

REDUCED PRESSURE PRINCIPLE DETECTOR ASSEMBLIES ARE:

AMES- 5000SS, (5001SS & 5001SSN & 5001SSZ 3"-6"), (Colt500 2½"-10") (Colt500A 2½"-10"), (Colt500N 2½"-10"), (Maxim500 2½"-8")
(Maxim500A 2½"-8"), (Maxim500N 2½"-8")
BEECO-HERSEY- 6CMDA
CLAVAL- RD7LY
CONBRACO/APOLLO- 40-700, 40-70A, 40-70C, 40-70E, 40-70G, (4A-700 2½"-8), (4AN-700 2½"-8")
FEBCO- 826YD
WATTS- 009RPDA, 909RPDA, 990RPDA, 992RPDA, (957RPDA 2½"-10"), (957NRPDA 2½"-10"), (967NRPDA 2½"-3")
WILKINS- (975DA 2½"-10"), (375DA 2½"-10"), (375ADA & 375ADAR 2 ½"-10"), (375ASTDA 2 ½"-4), (475DA 4"-8"), (475DAV 4"-8")

SCDHEC

LIST OF APPROVED BACKFLOW PREVENTION ASSEMBLIES

REDUCED PRESSURE PRINCIPLE ASSEMBLIES

Approved for use to protect the potable water system from backflow when there is an actual or potential health hazard. The terms "health hazard" shall mean an actual or potential threat of contamination or pollution of a physical or toxic nature to the public potable water system or the consumer's potable water system to such a degree of intensity that there would be a danger to health.

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Ames	4000B	½", ¾", 1", 1¼", 1½", 2"
	4000-RP	4", 6", 8", 10"
	4000SS	¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	4001SS	3", 4", 6"
	4001SSN	3", 4", 6"
	4001SSZ	3", 4", 6"
	Colt400	2½", 3", 4", 6", 8", 10"
	Colt400N	2½", 3", 4", 6", 8", 10"
	Colt400Z	2½", 3", 4", 6", 8", 10"
	Maxim400	2½", 3", 4", 6", 8", 10"
Beeco-Hersey	Maxim400N	2½", 3", 4", 6", 8"
	Maxim 400Z	2½", 3", 4", 6", 8"
	6CM	2½", 3", 4", 6", 8", 10"
Buckner	6CM-Bronze	2½", 3", 4", 6", 8"
	FRP-II	¾", 1", 1¼", 1½", 2"
	24000 thru 24004	¾", 1", 1¼", 1½", 2"
Cash Acme	RP 100	¾", 1", 1½", 2"
	RP 200	½", ¾"
	RP 500	¾", 1"
Cla-Val	RP-2	¾", 1", 1¼", 1½"
	RP-4	2", 2½", 3", 4", 6", 8", 10"
	RP-4V	4"
	RP6LW	¾", 1", 1¼", 1½", 2"
	RP6VW	¾", 1", 1½", 2"
	RP7LW	2½", 3", 4", 6", 8", 10"
	RP7LY	2½", 3", 4", 6", 8", 10"
	RP8LW	2½", 3", 4", 6", 8", 10"
	RP8LY	2½", 3", 4", 6", 8"

REDUCED PRESSURE PRINCIPLE ASSEMBLIES CONTINUED:

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Cla-Val	RP8NW	2½", 3", 4", 6", 8", 10"
	RP8NY	2½", 3", 4", 6", 8"
	RP8VW	2½", 3", 4", 6", 8", 10"
	RP8VY	2½", 3", 4", 6"
Conbraco/Apollo	40-200 Series	¼", ¾", ½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	Stainless {40-204-A2S	¾
	Steel {40-205-A2S	1"
	RP4A	½", ¾", 1", 1¼", 1½", 2", 2½", "3", 4", 6", 8"
	RPLF4A	½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8"
	RP4AN	2½", 3", 4", 6", 8"
	RPLF4AN	2½", 3", 4", 6", 8"
Febco	825	2½", 3", 4", 6", 8", 10"
	825D	2½", 3", 4", 6", 8", 10"
	825Y	¾", 1", 1¼", 1½", 2", 2½"
	LF825Y	¾", 1", 1½", 2"
	825YD	2½", 3", 4", 6", 10"
	825YA & YR	¾", 1", 1½", 2"
	LF825YA	¾", 1", 1½", 2"
	835B	¾", 1", 1½", 2"
	860	¾", 1", 1½", 2", 2½", 3", 4", 6", 8"
	LF860	½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	LF860U	½", ¾", 1", 1¼", 1½", 2"
	880	2½", 3", 4", 6", 8", 10"
Flomatic	880V	2½", 3", 4", 6", 8", 10"
	LF880V	2½", 3", 4", 6", 8"
	RPZ	¾", 1", 1½", 2", 2½", 3", 4", 6", 8"
Watts	RPZII	½", ¾"
	RPZE	¾", 1", 1½", 2"
	909	2½", 3", 4", 6", 8", 10"
Watts	909QT	¾", 1", 1¼", 1½", 2"
	919QT	½", ¾", 1", 1¼", 1½", 2"
	009	2½", 3", 4", 6"
	009QT	¼", ¾", ½", ¾", 1", 1¼", 1½", 2"
	009M1 & M2QT	¾", 1", 1¼", 1½", 2"
	009M3QT	¾"

REDUCED PRESSURE PRINCIPLE ASSEMBLIES CONTINUED:

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Watts	990	4", 6", 8"
	992	4", 6", 8", 10"
	994	¾", 1", 1½", 2", 2½", 3", 4", 6", 8", 10"
	995	¾", 1", 1¼", 1½"
	957	2½", 3", 4", 6", 8", 10"
	957N	2½", 3", 4", 6", 8", 10"
	957Z	2½", 3", 4", 6", 8", 10"
	967	2½", 3", 4", 6", 8"
Wilkins	375	¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	375XL	½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	375XLB	¾", 1", 1½", 2"
	375A, AR, AXL, & ARXL	2½", 3", 4", 6", 8", 10"
	375AST	2½", 3", 4", 6", 8", 10"
	375ASTR	2½", 3", 4", 6"
	375ST	½", ¾", 1"
	375MS & XLMS	2½", 3", 4", 6", 8", 10"
	475	2½", 3", 4", 6", 8", 10"
	475XL, XLV, XLMS	2½", 3", 4", 6", 8", 10"
	475V, VMS, MS, & XLVMS	2½", 3", 4", 6", 8", 10"
	575	¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	975	¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	975A	¾", 1", 1¼", 1½", 2"
	975XLST	¾", ½"
	975XL	¼", ¾", ½", ¾", 1", 1¼", 1½", 2", 2½", 3", 4", 6", 8", 10"
	975XL2	¼", ¾", 1", 1¼", 1½", 2"
	975XL2V	¾", 1"
	975XL2MS & XL2BMS	¾", 1", 1¼", 1½", 2"
	975XL2TCU & XL2U	½", ¾", 1", 1¼", 1½", 2"
	975XL2SE & XL2SEU	¾", 1", 1½", 2"
	975XLD	¾"
	975XLV	¾", 1"
	975XLU	¾", 1", 1½", 2"
	975XLSE & XLSEU	¾", 1", 1¼", 1½", 2"
	975XLTCU & XLBMS	½", ¾", 1", 1¼", 1½", 2"
	975MS & BMS	2½", 3", 4", 6", 8", 10"
	975XLMS	¾", 1", 1¼", 1½", 2"

SCDHEC

LIST OF APPROVED BACKFLOW PREVENTION ASSEMBLIES

PRESSURE VACUUM BREAKERS

PVB's are approved for use when protecting the potable water system from backsiphonage only when a health hazard or non-health hazard is involved. The term "health hazard" shall mean an actual or potential threat of contamination or pollution of a physical or toxic nature to the potable water system or the consumer's potable water system to such a degree of intensity that there would be a danger to health. It is very important to understand that the PVB is not designed for backpressure. Also, the PVB must be installed 12" above any downstream plumbing.

<u>COMPANY</u>	<u>MODEL</u>	<u>SIZE</u>
Ames	A200	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 2"
Buckner	24199 thru 24204	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
	24199/25 thru 24204/25	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
Conbraco/Apollo	40-503-02 thru 40-508-02	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
	PVB4V	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
	PVB4A	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
Febco	765	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
	745	$\frac{3}{4}''$, 1"
	LF767FR	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
Flomatic	PVB	$\frac{3}{4}''$, 1"
Rain Bird	PVB-075-R thru 200-R	$\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
Watts	800QT	$\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
	800MQT	$\frac{1}{2}''$, $\frac{3}{4}''$
	800CMQT	$\frac{1}{2}''$, $\frac{3}{4}''$
	800M2QT	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
	800M3QT	$\frac{1}{2}''$, $\frac{3}{4}''$
	800M4FR	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
	800M4QT	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
Wilkins	720A	$\frac{1}{2}''$, $\frac{3}{4}''$, 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2"
	420	$\frac{1}{2}''$, $\frac{3}{4}''$, 1"
	420XL	$\frac{1}{2}''$, $\frac{3}{4}''$
	460	$\frac{3}{8}''$, $\frac{1}{2}''$, $\frac{3}{4}''$, 1"
	460XL	$\frac{3}{8}''$, $\frac{1}{2}''$, $\frac{3}{4}''$, 1"

BACKFLOW EQUIPMENT REPRESENTATIVES

Conbraco / Apollo

Mr. Larry Castleberry / Mr. Joey Smith
Pro Marketing, Inc
110 Corporate Dr / Suite L
Spartanburg SC 29303
864-578-4334 / 864-415-8696

TMS

Mr. Rick Wade / Mr. Donnie Johnson
3540 Rutherford Rd
Taylors SC 29687
864-268-2891
800-476-2212

BAVCO

Mr. Jim Purzycki
20435 South Susana Rd
Long Beach, CA 90810
800-458-3492
310-639-5231

Beeco - Hersey

Mr. Tod Little
Mueller Company
1437 Heins Rd
Blythewood SC 29016
803-691-9431

American Backflow Products

Mr. Mark Inman
7580-A West Tennessee Street
Tallahassee, FL 32303
800-575-9618 / 850-576-1814

Febco

Mr. M. C. Sorrell / Mr. Bob Buddo
Lewis Marketing
1511 Ameron Drive
Charlotte, NC 28206
704-376-0262

Watts & Ames

Mr. Joel Golmont / Mr. Mike Davis
Smith & Stevenson
P. O. Box 240009
Charlotte, NC 28224
800-225-9895 / 704-525-3388

Wilkins

Mr. Craig Birchfield
Quality Marketing
3500-C Woodpark Blvd
Charlotte, NC 28206
704-599-9407

Flomatic

Mr. Josh Amon / Mr. John Amon
Preferred Sources
930 Culp Road
Pineville NC 28134
704-504-3111

Cash-Acme / Flomatic

Mr. Dan Hunt / Mr. Allen Scott
3401 Woodpark Blvd Suite B
Charlotte NC 28206
704-921-8422

If you should have any questions concerning this list or need any assistance concerning backflow prevention or cross connection control, please call or write:

Mr. John Watkins, Cross Connection Control Program Coordinator
SCDHEC / Bureau of Water
2600 Bull Street
Columbia, SC 29201
803-898-3567 phone
803-898-3795 fax

SCDHEC backflow web page: www.scdhec.net/environment/water/dwbflow.htm

SECTION 3: TESTING REQUIREMENTS & LIST OF CERTIFIED TESTERS

When double check valves, pressure vacuum breakers or reduced pressure principle backflow prevention assemblies are installed in the system, routine testing will be performed by a certified tester. It is the duty of the customer/user at the location where the backflow prevention assembly is installed to have certified inspections and operational tests made at least once per year by a certified tester.

1. New assemblies will be tested by a certified tester after installation and before use by the customer.
2. Each assembly will be tested at least once per year by a certified tester.
3. All backflow prevention assemblies will be tested immediately after repairs of any kind are made.
4. In those instances where SC DHEC or LRWS deems the hazard to be great enough, certified inspections may be required at more frequent intervals.
5. Inspection and testing will be conducted at the expense of the water user.
6. A copy of the backflow prevention device inspection report and test results for all assemblies tested will be submitted by the certified tester and maintained on file by LRWS.
7. A written notification of the required inspection date will be sent to each customer annually. If the inspection report is not received by the required date, notification and disconnection of services will be carried out following LRWS policy for disconnection of services.
8. A list of certified testers will be made available to each customer required to annually test their backflow devices, if necessary (enclosed).

Aiken

Cert No.	Name	Employer	Address	Phone	Expires
102256918	Agliano, Nathan K	Cold Creek Nurseries	398 Hitchcock Pkwy	803-648-0329	06/30/18
102178916	Aiello, Christopher	Southern Plumbing & Electrical Inc	Po Box 327	803-649-3516	09/30/16
102103116	Anderson, Mike	Anderson Plumbing Company	975 Brookhaven Dr	803-648-3837	09/30/16
102215416	Berry, Jeff	Yohe Plumbing Of Aiken Inc	Po Box 3836	803-642-8900	03/31/16
102237816	Bowers, Blake C	Carolina Utilities & Services	509 Forest Cir	803-634-2586	06/30/16
102252018	Brewton, Joseph G	Kimballs Plumbing	1205 Pine Dr	803-648-4301	06/30/18
102238516	Brinkley, Norman C	Cleanco	1022 Hitchcock Dr	803-335-8535	06/30/16
102190217	Brown, Michael T	Brown Backflow Inspection	1858 Hidden Hills Dr	803-640-5926	09/30/17
102257518	Cannon, Stephen G	Stephen Cannon Irrigation Tec	156 Crosby Rd	803-507-1720	06/30/18
102183916	Carson, Theodore J	Ben Franklin Plumbing	10985 Atomic Rd	803-279-1771	12/31/16
102134316	Cooper, Samuel	Cooper'S Plumbing Inc	Po Box 7347	803-648-0203	06/30/16
102143518	Crenshaw, Paul B	Paul Crenshaw Plumbing Repairs	1118 Lake Ave	803-279-1964	12/31/18
102140416	Curtis, Roger A	Curtis Sprinklers	3050 Champagne Dr	803-640-3607	09/30/16
102260518	Darby, Edward M	Aiken Backflow Company	4352 Williston Rd	803-646-3836	09/30/18
102794117	Dicks, Jonathan R	Jonathan Dicks	245 Anthony Dr	803-392-7287	06/30/17
102249717	Ellis, Jonathan	Yohe Plumbing Of Aiken	Po Box 3836	803-642-8900	09/30/17
102234518	Fanning, Christopher C	Kimballs Plumbing	1205 Pine Dr Nw	803-648-4301	12/31/18
102023617	Goodwin, Gary G	Twin Systems Llc	168 Green Hill Rd	803-270-1986	06/30/17
102222118	Hair, Robert W	Cold Creek Nurseries	398 Hitchcock Pkwy	803-648-6810	06/30/18
102239816	Hamilton, Harry P	Armstrong & Johnston	1939 University Pkwy	803-641-9885	09/30/16
102190817	Harden, James F JR	Rivercity Mechanical Llc	1915 White Pine Dr	706-831-6190	06/30/17
102182416	Hurt, Steve A	S & H Home Improvements	1427 S Boundary Ave Se	803-215-2659	12/31/16
102140516	Jolley, Paul M	Eddington Sprinkler Services	1217 Evans Rd	803-507-4441	12/31/16
102163116	Lanier, Relferd R III	Carolina Utilities & Services	619 Howlandville Rd	803-221-6122	06/30/16
102191217	Lard, Nicholas T	Nicholas Lard	119 Aumont Pl	803-617-8138	06/30/17
102024719	Mcneill, James C	Mcneill Plumbing	5061 Sizemore Cir	803-643-0433	03/31/19
102215319	Mcneill, Shawn C	Mcneill Plumbing	5061 Sizemore Cir	803-643-0433	03/31/19
102164216	Minor, James T	Simplex Grinnell	23 Senn St	803-223-4478	03/31/16
102080816	Nix, Harris M	Southern Plumbing & Electrical Inc	Po Box 327	803-649-3516	09/30/16
102026517	Owen, Randall W	Randy Owen Plumbing Llc	Po Box 6302	803-507-0298	06/30/17
102089617	Pace, Geoffrey	Pace & Son Plumbing	14 W R Busbee Rd	803-331-7383	12/31/17
102206416	Prosser, Terry W	Curb Appeal Landscaping & Irrigatio	156 Sudlow Hills Ct	803-646-8000	03/31/16
102137517	Randall, Michael W	Bradley Plumbing & Heating Inc	190 Rutland Dr Nw	803-649-2155	03/31/17
102055217	Redd, Timothy W	Bradley Plumbing & Heating Inc	Po Box 460	803-649-2155	12/31/17
102268018	Shealy, Jason C	J S Backflow Testing Llc	140 Rainbow Falls Rd	803-232-1708	06/30/18

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 2 of 38

Cert No.	Name	Employer	Address	Phone	Expires
102258718	Steelman, Nathan L	J S Backflow Testing	140 Rainbow Falls Rd	803-232-1708	06/30/18
102240416	Sutton, Brandon L	Affordable Plumbing Company	325 Woodland Dr	803-221-1777	09/30/16
102110819	Swearingen, Lewis C JR	Kimballs Plumbing	1205 Pine Dr Nw	803-648-4301	03/31/19
102001516	Turner, David L JR	Turner Mechanical Inc	12384 Atomic Rd	803-442-4474	03/31/16
102046118	Wade, John B	John Wade Plumbing Inc	Po Box 1172	803-649-2124	09/30/18
102273219	Walker, Doug	Kimballs Plumbing	1205 Pine Dr Nw	803-648-4301	03/31/19
102079317	Widener, Elvin C	Pipeworks Inc	Po Box 619	803-270-0950	12/31/17

Total: 42

Anderson

Cert No.	Name	Employer	Address	Phone	Expires
104285418	Adams, Robert S	R S A Cross Connection Control	319 Thompson St	864-352-6390	09/30/18
104263818	Auletti, Daniel J	Haneys Backflow Services	5206 Slater Rd	864-437-4269	12/31/18
104219917	Beauregard, Robert R	Mr Rooter Plumbing Of Anderson	130 Powell Rd	864-964-9366	06/30/17
104218416	Blanton, Edward E	Upstate Calibration & Controls Inc	17829 Brown Ave Ext	864-617-1851	12/31/16
104168516	Brooks, Tommy	Tommy Brooks Services	1504 James Cox Rd	864-940-1976	09/30/16
104216217	Burdette, James C	Chads Backflow	1203 Westgate Rd	864-760-8485	12/31/17
104237716	Cavedo, William G		2308 Whitehall Ave	864-934-2833	03/31/16
104134616	Coker, Darrin R	Phlow Guard	237 Stevenson Dr	864-844-2078	03/31/16
104182917	Coker, Jessie J	Mr Rooter Plumbing Of Anderson	130 Powell Rd	864-964-9366	09/30/17
104285517	Crocker, Christopher B	Brians Backflow	Po Box 844	864-934-9230	06/30/17
104285718	Gailey, William D JR	Daves Backflow	3912 Hwy 29 S	864-760-7287	09/30/18
104187519	Gallegos, Fred G	Freds Backflow	149 Coker Cir	864-338-7834	03/31/19
104123516	Glenn, John W JR	Glenn Plumbing Company	481 E Whitner St	864-224-0781	03/31/16
104046419	Glenn, John W SR	Glenn Plumbing Company	481 E Whitner St	864-224-0781	03/31/19
104149919	Glenn, Patrick L	Glenn Plumbing Company	481 E Whitner St	864-934-1083	03/31/19
104791518	Griffin, Rickey A	Griffins Quality Services	2613 Shady Grove Rd	864-245-5553	09/30/18
104231718	Haney, Joshua D	Haneys Backflow Services	5206 Slater Rd	864-437-4269	12/31/18
104058717	Head, Morris K	Carolina Cross Connection	106 Ruhamah Church Rd	864-375-9102	03/31/17
104251117	Jones, Dennis E	Total Fire Protection	2207 Beaver Dam Rd	864-958-2786	12/31/17
104040117	Kelly, Bill A	Service Laundry Machinery	Po Box 209	864-338-5502	12/31/17
104266418	Lewis, Larry D	Lewis Mechanical	512 Elderberry Ln	864-350-7475	06/30/18
104109517	Lindsay, Kyle	Kyles Backflow Testing	110 Greenforrest Dr	864-933-1737	06/30/17
104025416	Locke, Larry	Locke Backflow Testing	503 Locke Rd	864-369-7501	09/30/16
104225917	Marcus, Joseph C	A - 1	325 Walnut Dr	864-430-2913	12/31/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16

Page 3 of 38

Cert No.	Name	Employer	Address	Phone	Expires
104238716	Martin, Terry W	Glenn Plumbing Company	481 E Whitner St	864-224-0781	06/30/16
104251417	McCullough, Bobby	Jesus Christ Mobile Ministries	Po Box 1407	864-321-0609	12/31/17
104238616	Mitchell, Brandon M	Aarics Irrigation And Backflow Testin	106 Skinner Ln	864-356-5447	06/30/16
104249817	Norton, Matthew	Mr Rooter Plumbing	130 Powell Rd	864-964-9366	09/30/17
104243716	Norwood, Bryan	Roto Rooter Plumbers	500 Mcgee Rd	864-288-7686	12/31/16
104202018	Owens, Alton S	Owens Plumbing	Po Box 13577	864-934-4393	06/30/18
104025516	Singleton, Derrick B	S & S Backflow Testing	2708 Waccamaw Trail	864-617-3976	12/31/16
104260218	Sloan, Joseph C	Artisan Works	105 Lyndhurst Dr	864-356-4546	09/30/18
104065716	Sweet, Jonathan D	Durham'S Pump & Motors	139 Fox Valley Dr	864-845-7223	06/30/16
104120818	Vuknic, Edward J	Reeves Irrigation	118 Sunrise Harbour	864-940-3134	12/31/18
104136417	Waters, Jefferson L	Daves Backflow	3912 Hwy 29 S	864-224-9544	09/30/17
104234018	Whisnant, Robert B	R B W Backflow Service	2013 Quail Ridge Rd	864-634-8119	12/31/18

Total: 36

Barnwell

Cert No.	Name	Employer	Address	Phone	Expires
106131916	Frederick, Jimmy W	Pro Test Llc	152 Dunlap Cir	803-645-1412	09/30/16
106271319	Hutto, Michael W	Wades Repair Service Inc	13534 Sc Hwy 64	803-259-1749	03/31/19
106104517	Jackson, Adam W	Wade'S Repair Service	13534 Hwy 64	803-259-1749	06/30/17
106104717	Jackson, Rusty A	Wade'S Repair Service	13534 Hwy 64	803-259-1749	06/30/17

Total: 4

Beaufort

Cert No.	Name	Employer	Address	Phone	Expires
107207217	Alexander, Joshua L	Whitmore Plumbing	Po Box 556	843-524-3911	09/30/17
107261918	Aparicio, Jorge A	Piper Plumbing Llc	Po Box 5264	843-686-5972	12/31/18
107043216	Borasky, Jeffrey M	Low Country Backflows Llc	2 Fishermans Bend Ct	843-422-3494	03/31/16
107240916	Bullard, Thomas	Southeastern Fire Services Llc	1306 Fording Island Rd Ste 1Bluffton, SC 29910	843-706-9400	09/30/16
107095216	Burtron, Robert G	R & B Plumbing, Heating, & Air	6 Burlington Land Rd	843-263-6904	03/31/16
107028718	Carr, Charlie F	Coastal Pipe & Fire Solutions	30 Sugaree Dr	843-706-3919	06/30/18
107221618	Dasher, Timothy G	Bluffton Plumbing Company	Po Box 937	843-757-2902	06/30/18
107165018	Dobson, George M	Piper Plumbing	21 Mathews Dr Ste 5	843-686-5972	03/31/18
107008619	Doty, Jay A SR	Alarm Fire & Security Llc	9 Hunter Rd	843-422-3236	03/31/19
107246317	Doty, Jay JR	Alarm Fire & Security	Po Box 7972	843-842-6100	06/30/17
107089916	Drennen, Lloyd L	Drennen Maintenance	Po Box 907	843-683-1210	03/31/16

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16

Page 4 of 38

Cert No.	Name	Employer	Address	Phone	Expires	
107190717	Drew, Jamie K	Low Tide Plumbing	Po Box 22717	843-682-8248	12/31/17	
107272319	Ernst, Edwin R	Coastal Carolina Specialty	13 Azalea St	843-247-0349	03/31/19	
107794217	Fiore, Gerard J	Jerry The Plumber	71 Shelburne St	843-837-8599	06/30/17	
107002218	Gable, Ronald T	The Greenery Inc	93 Arrow Rd	843-785-3848	12/31/18	
107171218	Goodrich, Grant A	Alarm Fire Security Llc	9-D Hunter Rd	843-842-6100	12/31/18	
107235216	Griffin, Cornelius	Coastal Pipe & Fire Solutions	30 Sugaree Dr	843-706-3919	03/31/16	
107245617	Hardy, Jeffrey B	The Greenery Inc	Po Box 6569	843-785-3848	03/31/17	
107262618	Hill, Joseph B	Piper Plumbing Llc	Po Box 5264	843-686-5972	12/31/18	
107185918	Humbert, Cecil L JR	The Greenery Inc	93 Arrow Rd	843-785-3848	12/31/18	
107088417	Jarvis, Robert M	Jarvis Plumbing	Po Box 22595	843-247-3291	06/30/17	
107235116	Kraner, Malinda S	Beaufort Backflows	5 Tucker Ave	843-525-6999	03/31/16	
107244717	Lang, Christopher S	Low Country Fire & Safety	8-D Cardinal Rd	843-689-3836	03/31/17	
107224317	Lyons, Christopher B	Keiths House Of Plumbing	Po Box 815	843-524-2138	12/31/17	
107244817	Mccall, Eric B	The Greenery Inc	960 William Hilton Pkwy	843-247-9623	03/31/17	
107130916	Mellott, Brian E	Eagle Fire Inc	1 Fernbank Ave	843-605-3119	03/31/16	
107273419	Mosher, Jon E	Cornerstone Plumbing Llc	Po Box 4272	843-812-8153	03/31/19	
107062616	Paxton, David L	D L P Fire Protection Group Llc	1306 Fording Island Rd Ste 1	Bluffton, SC 29910	843-706-9400	12/31/16
107235416	Posey, Lucas M	The Greenery Inc	960 William Hilton Pkwy	843-379-5263	03/31/16	
107247617	Ricker, Robert G	Coastal Pipe & Fire Solutions	30 Sugaree Dr	843-706-3919	09/30/17	
107253718	Roseneau, Preston	Beaufort Backflows	5 Tucker Ave	843-525-6999	03/31/18	
107151417	Roseneau, Randy L	Beaufort Backflows	5 Tucker Ave	843-525-6999	06/30/17	
107078117	Stokes, Daniel	Ocean Wood Landscaping Compan	67 Union Cemetary Rd	843-682-4000	12/31/17	
107002518	Voss, Ronald A	Voss Irrigation Services Inc	Po Box 6012	843-247-2965	12/31/18	
107192516	Walters, Daniel	Alarm, Fire, And Security	Po Box 7972	843-842-6100	09/30/16	
107227418	Webb, Waylon C	Piper Plumbing Home & Commercial	21 Mathews Dr Ste 5	843-686-5972	03/31/18	
107055917	Youmans, Kevin	Sentry Sprinklers Inc	Po Box 23468	843-681-4742	03/31/17	
107216817	Youmans, Michael	Sentry Sprinklers Inc	Po Box 23468	843-681-4742	03/31/17	

Total: 38

Berkeley

Cert No.	Name	Employer	Address	Phone	Expires
108228018	Buck, George JR	Lowcountry Fire & Safety Llc	339 Annette Dr	843-216-1234	03/31/18
108245217	Doll, Charles D	Aqua-Doc	8204 Brookstone Way	843-442-6375	03/31/17
108273119	Goddard, Kenneth O JR	Unifour Fire & Safety	1066-C Royle Rd	843-531-0789	03/31/19
108031816	Gordon, Barry K	B H M Backflow Inc	116 Margate Cir	843-693-6030	06/30/16

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16

Page 5 of 38

Cert No.	Name	Employer	Address		Phone	Expires
108222017	Hampton, Roger R	Hampton Environmental	219 Meadow Wood Rd	Summerville, SC 29483	843-810-2641	06/30/17
108257418	Harris, Daniel S	Hardy Services Group	1068 Clements Ferry Rd	Wando, SC 29492	843-881-3344	06/30/18
108796316	Hubbard, Newman		3551 Galaxy Rd	Ladson, SC 29456	843-693-8579	09/30/16
108100416	Maccubbin, Robert O JR	Coastal Lawn Service	612 Butter Rd	Bonneau, SC 29431	843-200-5718	03/31/16
108101519	Maccubbin, Robert O SR	Coastal Lawn Management Llc	612 Butter Rd	Bonneau, SC 29431	843-200-5719	03/31/19
108227718	Moorman, Sean A	Moorman'S Plumbing	1605 Church Hill Rd	Moncks Corner, SC 29461	843-761-4461	03/31/18
108070818	Redders, Claremont W	S & K Backflow Testing & Repair Llc	231 Winter Ct	Moncks Corner, SC 29461	843-312-2193	03/31/18
108254618	Rippee, Lisa M	Carnes Crossroads Backflow	358 Oyster Bay Dr	Summerville, SC 29483	843-259-6269	03/31/18
108259918	Simpkins, Randall T	Unifour Fire & Safety	816 Lecture Dr	Ladson, SC 29456	828-455-2126	09/30/18
108117318	Stone, Monroe M	Tri County Backflow	307 Archibald Dr	Goose Creek, SC 29445	843-568-4078	03/31/18
108273519	Wolfe, Cecil W III	Action Plumbing	Po Box 614	Goose Creek, SC 29445	843-209-3494	03/31/19

Total: 15

Charleston

Cert No.	Name	Employer	Address		Phone	Expires
110099917	Adams, Richard C	Adams Backflow Testing	445 Folly Rd	Charleston, SC 29412	843-991-6734	03/31/17
110243216	Alford, Joe W	Fire & Life Safety America	2154 N Center St Ste C-306	North Charleston, SC 29406	843-305-9001	12/31/16
110242916	Anderson, James R II	Simplex Grinnell	5935 Rivers Ave Ste 105	North Charleston, SC 29406	843-747-5254	12/31/16
110219117	Barteet, Joseph D	Blitch Plumbing	Po Box 13480	Charleston, SC 29422	843-795-9674	03/31/17
110092218	Bataller, Dominick J	Nicks Plumbing	1789 Brittlebush Ln	Johns Island, SC 29455	843-858-4085	06/30/18
110115818	Bates, Steven S	E L I Inc	1555 Joe Rouse Rd	Mount Pleasant, SC 29466	843-849-1389	06/30/18
110035716	Bessinger, Jimmy W	Bessingers Backflow Service	1253 Dickson Ave Ste 110	Hanahan, SC 29410	843-406-9228	03/31/16
110075418	Beverly, Marshall A III	Beverly Plumbing	3026 Plowground Rd	Johns Island, SC 29455	843-559-5732	06/30/18
110148917	Brenneman, Jarrad A	Bessingers Backflow Service	1253 Dickson Ave Ste 110	Hanahan, SC 29410	843-406-9228	09/30/17
110217017	Britton, Charles E	Eli Inc	1555 Joe Rouse Rd	Mount Pleasant, SC 29466	843-514-2310	03/31/17
110230418	Britton, Eric P	Affordable Jo'S Backflow	1044 Summerall Rd	Johns Island, SC 29455	843-559-2801	09/30/18
110230618	Britton, Jo P	Affordable Jo'S Backflow	1044 Summerall Rd	Johns Island, SC 29455	843-559-2801	09/30/18
110159917	Brown, Barry	Barry Brown Backflow Testing	1225 Lieben Rd	Mount Pleasant, SC 29466	843-607-3017	12/31/17
110218817	Brown, Glenn M	Rain Irrigation & Backflow	1019 Fort Sumter Dr	Charleston, SC 29412	843-789-0084	03/31/17
110174416	Burgess, Ronnie W JR	Carolina Turf Irrigation	1047 Harborview Rd	Charleston, SC 29412	803-420-1441	03/31/16
110141817	Burgess, Ronnie W	Carolina Turf Irrigation	1047 Harborview Rd	Charleston, SC 29412	843-696-5640	03/31/17
110152118	Burgess, Thomas T	Carolina Turf Irrigation	1047 Harborview Rd	Charleston, SC 29412	843-696-1796	03/31/18
110084318	Calogrides, Peter D	Backflow Testing Services	Po Box 80023	Charleston, SC 29416	843-303-0832	12/31/18
110219317	Chabera, James R	Cruz Enterprises	2468 Cape Rd	Johns Island, SC 29455	843-559-5188	03/31/17
110240616	Chambers, Erin M	Lowcountry Fire & Safety	457-G Jessen Ln	Charleston, SC 29492	843-216-1234	09/30/16

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16

Page 6 of 38

Cert No.	Name	Employer	Address	Phone	Expires
110255318	Clarke, Doug J	Advanced Backflow Testing & Repair	295 Seven Farms Dr C-148 Daniel Island, SC 29492	843-405-1050	03/31/18
110156717	Cleveringa, Stanton L	Daniel Island Backflow	12 Grove Ln Charleston, SC 29492	843-906-1658	12/31/17
110240116	Cohen, Jeff	C & P Backflow	2311 Tall Sail Dr Unit G Charleston, SC 29414	843-270-2649	09/30/16
110253918	Cole, Albert F JR	Fire & Life Safety America	2154 N Center St C-30 North Charleston, SC 29406	843-367-5327	03/31/18
110251918	Collins, Bryan A	Simplex Grinnell	1141 Remount Rd Ste 400 North Charleston, SC 29406	843-747-5254	06/30/18
110235816	Cote, George C	Bessingers Backflow Service	1253 Dickson Ave Ste 110 Hanahan, SC 29410	843-406-9228	03/31/16
110229918	Creech, Graham	Flo Testing	831 Erckmann Dr Mount Pleasant, SC 29464	843-270-7991	06/30/18
110254418	Crudden, Ciaran	V S C Fire & Security	453 Jessen Ln Charleston, SC 29492	843-416-1300	03/31/18
110042317	Cumbee, Gene	Cullum Mechanical	3325 Pacific St North Charleston, SC 29418	843-214-1421	03/31/17
110209916	Daniel, Oscar T JR	Tri-County Backflow	410 Blue Dragonfly Dr Charleston, SC 29414	843-696-5649	03/31/16
110180216	Davis, Christopher R	Coastal Utilities LLC	5185 Chisolm Rd Johns Island, SC 29455	843-514-2986	09/30/16
110062318	Davis, Philip M JR	Ground Hog Utilities	Po Box 487 Johns Island, SC 29457	843-559-5999	03/31/18
110242316	Dunlap, Gustave K	Liberty Fire Protection Inc	2181 Till Rd Charleston, SC 29414	843-277-4059	12/31/16
110041517	Dyson, Steven W	Dyson Services LLC	1285 Yeamans Hall Rd Hanahan, SC 29410	843-300-8109	12/31/17
110199018	Endsley, Ann	Ann'S Backflow Testing	Po Box 62352 North Charleston, SC 29406	843-200-2321	03/31/18
110051718	Epp, Steven	Irrigation By Design	4337 Waterview Cir Charleston, SC 29418	843-552-3078	06/30/18
110254518	Ferrazzano, Michael	Community Management Group	349 Folly Rd Ste 2b Charleston, SC 29412	843-795-8484	03/31/18
110244417	Figliorelli, Thomas	Bishop & Sons Plumbing & Piping Inc	Po Box 12266 Charleston, SC 29422	843-795-6990	03/31/17
110188317	Fishburne, Henry F	Carolina Rain	1645 Pin Oak Cut Mount Pleasant, SC 29466	843-408-2203	03/31/17
110096816	Fry, Chris R	Irrigation & Lighting Specialties	2245-C Ashley Crossing Dr #Charleston, SC 29414	843-224-4846	12/31/16
110254018	Futrell, Felix	Blitch Plumbing	Po Box 13480 Charleston, SC 29422	843-795-9674	03/31/18
110049418	Geddes, David M	Ashley Plumbing Company	195 Rutledge Ave Charleston, SC 29403	843-514-9765	12/31/18
110218917	Gomez, Joseph	Simplex Grinnell	5935 Rivers Ave Ste 105 North Charleston, SC 29406	843-747-5254	03/31/17
110142417	Goodwin, Timothy M	C & T Services	Po Box 1672 Folly Beach, SC 29439	843-588-0099	03/31/17
110189218	Hall, William A	Simplex Grinnell	1141 Remount Rd Ste 400 North Charleston, SC 29406	843-747-5254	06/30/18
110241116	Harbin, James A	Pleasant Places Landscape	449 Longpoint Rd Mount Pleasant, SC 29464	843-881-3430	09/30/16
110288416	Harley, Michael J	Atlantic Plumbing Services	636-G Long Point Rd #4 Mount Pleasant, SC 29464	843-884-9444	03/31/16
110249917	Haynes, Shawn A	R & G Plumbing & Sewer Service Inc	Po Box 60835 Charleston, SC 29419	843-553-9997	12/31/17
110258818	Hefner, Robert	Rea Landscaping Management LLC	2544-H Ashley River Rd Charleston, SC 29414	843-576-4502	06/30/18
110007116	Hempton, John A	Hempton Plumbing & Electric	2734 Bohicket Rd Johns Island, SC 29455	843-200-1648	03/31/16
110056817	Hennon, John M	Bessingers Backflow Service	1253 Dickson Ave Ste 110 Hannahan, SC 29410	843-406-9228	09/30/17
110198918	Hill, Daniel E	Dan'S Backflow	5175 Forest Oaks Dr Hollywood, SC 29449	843-557-3812	09/30/18
110236116	Hopkins, William M	Charleston Backflow Testing & Service	554 Heron Point Blvd Mount Pleasant, SC 29464	843-670-8828	03/31/16
110272719	Hoppmann, Louis J III	Unifour Fire & Safety	780 Cartwright Dr Charleston, SC 29414	843-303-3220	03/31/19
110102917	Hough, Ray A	Aardvark Plumbing	875-A Walt Miller Rd Mount Pleasant, SC 29464	843-881-2333	09/30/17
110102718	Howcroft, Alex J	Rooter Man Plumbing	Po Box 30098 Charleston, SC 29417	843-766-3311	06/30/18

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16

Page 7 of 38

Cert No.	Name	Employer	Address		Phone	Expires
110140717	Hudson, James C	J H C Home Repair	880 Mikell Dr	Charleston, SC 29412	843-618-0779	03/31/17
110211216	Hunt, Michael C	Affordable Backflow Services	717 Tallwood Rd	Charleston, SC 29412	843-327-9677	03/31/16
110137116	Johnson, Russell K	Sentry Management Inc	4925 Lacross Rd Ste 112	N Charleston, SC 29406	843-795-0190	03/31/16
110260418	Kelley, Thomas D	Toms Backflow Testing	8737 Evangeline Dr	North Charleston, SC 29420	843-900-6857	09/30/18
110051616	Knapp, Marc K	Charleston Site Utilities, Llc	Po Box 30794	Charleston, SC 29417	843-870-7055	12/31/16
110140918	Knight, Chris	Bishop & Sons Plumbing	Po Box 12266	Charleston, SC 29422	843-795-6990	06/30/18
110249217	Kocak, Kyle	Austin Outdoor	7316 Peppermill Pkwy	North Charleston, SC 29418	843-225-2380	09/30/17
110164617	Lankford, Clint	Rooter Man Plumbing	Po Box 30098	Charleston, SC 29417	843-766-3311	09/30/17
110174516	Lawlis, Michael F	Simplex Grinnell	5935 Rivers Ave Ste 105	North Charleston, SC 29406	843-747-5254	03/31/16
110235316	Lazicki, Glenda F	Ashley Plumbing Company Inc	195 Rutledge Ave	Charleston, SC 29403	843-723-2814	03/31/16
110236516	Lee, John T		683 Fort Sumter Dr	James Island, SC 29412	843-513-5885	03/31/16
110116218	Lenhart, Daniel M	Affordable Lowcountry Tester	12 Casa Bianca Dr	Charleston, SC 29407	843-209-7873	06/30/18
110047718	Marks, James E III	Water Works	1828 Hubbell Dr	Mount Pleasant, SC 29466	843-856-8727	06/30/18
110130016	Marks, Michael R	Backflows N Stuff	2088 Church Creek Dr	Charleston, SC 29414	843-693-1966	03/31/16
110244016	Martin, Chris S	Fire & Life Safety America	2154 N Center St Ste C-306	North Charleston, SC 29406	843-305-9001	12/31/16
110241316	Martin, Chris		1625 Wayah Dr	Charleston, SC 29414	843-860-8187	09/30/16
110185617	Martin, James O	Lankford Plumbing	1259 Dickson Ave	Hanahan, SC 29410	843-747-8604	03/31/17
110254318	Mason, Gerard	Community Management Group	349 Folly Rd Ste 2b	Charleston, SC 29412	843-795-8484	03/31/18
110007718	Mathewes, Ronald W	Coastal Plumbing	419 Anita Dr	Goose Creek, SC 29445	843-863-8914	12/31/18
110235916	Mcdowell, Donald	Pye Barker Fire & Safety Inc	3898 Leeds Ave	North Charleston, SC 29405	843-767-3080	03/31/16
110286018	Mcgarry, Patrick K III	Eagle Fire Inc	3125 Ashley Phosphate Rd	North Charleston, SC 29418	843-225-2898	06/30/18
110185317	Mckay, Mark D	Precision Fire Systems	7385 W Spartan Blvd	N Charleston, SC 29418	843-767-0117	03/31/17
110263418	Mcmullan, James R	Liberty Fire Protection Inc	Po Box 42239	Charleston, SC 29423	843-552-1301	12/31/18
110032416	Michel, John P IV	Blitch Plumbing	Po Box 13480	Charleston, SC 29422	843-795-9674	09/30/16
110252318	Militello, Mark	Simplex Grinnell	1141 Remount Rd Ste 400	North Charleston, SC 29406	843-747-5254	06/30/18
110255218	Milkowski, Thomas A	Liberty Fire Protection Inc	Po Box 42239	Charleston, SC 29423	843-552-1301	03/31/18
110227918	Miller, Andy	Pye Barker Fire & Safety	3898 Leeds Ave	North Charleston, SC 29405	843-767-3080	03/31/18
110244517	Mitchell, Cord	Bishop & Sons Plumbing & Piping Ir	Po Box 12266	Charleston, SC 29422	843-795-6990	03/31/17
110239116	Morgan, John D	Coastal Golf & Landscape Services	741 Milldenhall Rd	Mount Pleasant, SC 29464	770-652-4572	06/30/16
110174116	Murray, Steve R	Simplex Grinnell	5935 Rivers Ave Ste 105	North Charleston, SC 29406	843-747-5254	12/31/16
110209616	Mykols, Daniel A	Harbor Home Watch, Llc	4014 Crown Pointe	Daniel Island, SC 29492	843-566-5169	03/31/16
110049118	Naumann, Al	Al Naumann Plumbing Inc	Po Box 565	Johns Island, SC 29457	843-296-3472	06/30/18
110197216	Olson, David	Lawn-O-Green	3350 Hill Park Rd	North Charleston, SC 29418	843-552-6610	03/31/16
110238316	Osborne, Michael D	Liberty Fire Protection Inc	Po Box 42239	Charleston, SC 29423	843-513-3745	06/30/16
110210917	Palomar, Cesar C	The Greenery Of Charleston Llc	8111 Pleasant Ridge Dr	N Charleston, SC 29420	843-884-0084	03/31/17
110235716	Parker, Bradley	Pye Barker Fire & Safety Inc	3898 Leeds Ave	North Charleston, SC 29405	843-767-3080	03/31/16

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16

Page 8 of 38

Cert No.	Name	Employer	Address		Phone	Expires
110222217	Passailaigue, Ray	Backflow Service & Repair	4706 Mimosa St	North Charleston, SC 29405	843-224-1396	06/30/17
110250017	Pennix, Timothy J	Adaptive Services	1253 Dogpatch Ln	Johns Island, SC 29455	843-480-9569	12/31/17
110266018	Pierce, Robert C	Eagle Fire Inc	3125 Ashley Phosphate Rd	North Charleston, SC 29418	843-225-2898	06/30/18
110237216	Pierce, William	Rusty'S Irrigation	117 Dorothy Dr	Charleston, SC 29414	843-708-4232	03/31/16
110273019	Pinckney, Carnell	Blitch Plumbing	Po Box 13480	Charleston, SC 29422	843-795-9674	03/31/19
110216716	Rabon, Stephen D II	V S C Fire & Security	453 Jessen Ln	Charleston, SC 29492	843-297-0056	12/31/16
110796118	Rine, Timothy D	Triad Mechanical Contractors	Po Box 31518	Charleston, SC 29417	843-556-5636	03/31/18
110271819	Riser, Robert L II	Yellowstone Landscape	7325 Peppermill Pkwy	North Charleston, SC 29418	843-225-2380	03/31/19
110263918	Roberts, Freddy E	James F Pedersen Company	5568 Hwy 162	Hollywood, SC 29449	843-889-8210	12/31/18
110243016	Robinson, Richard R	Bessingers Backflow Service	1253 Dickson Ave Ste 110	Hanahan, SC 29410	843-406-9228	12/31/16
110256018	Schwartz, William C	Bessingers Backflow Service	1253 Dickson Ave Ste 110	Hanahan, SC 29410	843-406-9228	06/30/18
110181216	Sharp, Brian L	V S C Fire & Security	453 Jessen Ln	Charleston, SC 29492	843-619-1488	09/30/16
110052918	Simmons, Tony A	T S I	Po Box 40251	Charleston, SC 29423	843-270-5193	06/30/18
110254118	Sowerby, Jay S	V S C Fire & Security	453 Jessen Ln	Charleston, SC 29492	843-416-1300	03/31/18
110259318	Spurzem, Jason R	Rooter Man Plumbing	Po Box 30098	Charleston, SC 29417	843-766-3311	06/30/18
110115716	Stelljes, Dietrick	Eli Inc	1555 Joe Rouse Rd	Mount Pleasant, SC 29466	843-849-1389	09/30/16
110235616	Stewart, Mike	Suppression Systems Inc	7148 Cross County Road A5	North Charleston, SC 29418	843-225-5959	03/31/16
110182316	Strehle, Tom A	Sunburst Landscaping Inc	3575-D Maybank Hwy Suite 2	Johns Island, SC 29455	843-768-2434	12/31/16
110240516	Sturgill, Robert B	Pleasant Places Inc	449 Longpoint Rd	Mount Pleasant, SC 29464	843-881-3430	09/30/16
110060616	Sueverkruepp, Donald W	Don'S Handyman Service	882 Piccadilly Cir	Charleston, SC 29412	843-224-2549	09/30/16
110175916	Sumner, Todd H	Todd Sumner Construction Llc	978 Three Trees Rd	James Island, SC 29412	843-723-6490	03/31/16
110158816	Svagerko, John E	The Greenery	489 Deanna Ln Ste A	Charleston, SC 29492	843-200-7126	03/31/16
110244617	Sweeney, Patrick A	V S C Fire & Security	453 Jessen Ln	Charleston, SC 29492	843-416-1300	03/31/17
110256418	Taylor, Vauntorian	Simplex Grinnell	1141 Remount Rd Ste 400	North Charleston, SC 29406	843-747-5254	06/30/18
110148617	Thompson, Steven B	Irrigation By Design	4337 Waterview Cir	Charleston, SC 29418	843-367-3347	09/30/17
110254718	Turgeon, Reuben M	Cruz Enterprises	2468 Cape Rd	Johns Island, SC 29455	843-559-5188	03/31/18
110244317	Tyler, Mathew	Pye Barker Fire & Safety	3898 Leeds Ave	North Charleston, SC 29405	843-767-3080	03/31/17
110197318	Walker, Samuel K	Lawn-O-Green	Po Box 40248	Charleston, SC 29423-0248	843-552-6610	03/31/18
110039816	Wallace, Ronald R	Ronald R Wallace	6189 Hyde Park Rd	Ravanel, SC 29470	843-364-9313	12/31/16
110035617	Watson, Anthony G	Blitch Plumbing	403 Fleming Rd	Charleston, SC 29412	843-795-9674	09/30/17
110173916	Weber, Shawn S	Simplex Grinnell	5935 Rivers Ave Ste 105	North Charleston, SC 29406	843-747-5254	03/31/16
110231618	Widener, Jamie P	Liberty Fire Protection Inc	7214 Peppermill Pkwy	N Charleston, SC 29418	843-513-4510	09/30/18
110113716	Youngblood, Charlie S	Simplex Grinnell	5935 Rivers Ave Ste 105	North Charleston, SC 29406	843-747-5254	03/31/16
110096417	Zelasko, Jon J JR	Z'S Irrigation & Lighting Llc	50 Peppertree Ln	Charleston, SC 29420	843-330-8714	03/31/17

Total: 126

Cherokee

Cert No.	Name	Employer	Address	Phone	Expires
111019216	Allison, Jody E	I C R Plumbing System Inc	734 Pacolet Hwy	Gaffney, SC 29340	864-489-8987 03/31/16
111175016	Blackwell, Billy E	B & B Home Improvements	485 Corinth Rd	Gaffney, SC 29340	864-489-6681 09/30/16
111178616	Childers, Mike	I C R Plumbing Systems Inc	734 Pacolet Hwy	Gaffney, SC 29340	864-489-8987 03/31/16
111107217	Dase, Greg R	The Plumbing Doctor	124 Bens Farm Rd	Gaffney, SC 29341	864-489-6584 06/30/17
111086117	Gordon, Ricky E	The Plumbing Doctor	124 Bens Farm Rd	Gaffney, SC 29341	864-489-6584 06/30/17
111107018	Lester, Donald E JR	Icr Plumbing Systems Inc	734 Pacolet Hwy	Gaffney, SC 29340	864-489-8987 06/30/18
111258618	Lester, Matthew T	Icr Plumbing Systems Inc	734 Pacolet Hwy	Gaffney, SC 29340	864-489-8987 06/30/18
111091619	Lowry, James T	Lowry Utilities Inc	Po Box 1256	Gaffney, SC 29342	864-490-3595 03/31/19
111022416	Phillips, Dane L	D & S Plumbing	3009 Union Hwy	Gaffney, SC 29340	864-490-0247 12/31/16
111207916	Rose, William AJR	Applied Backflow Pros	Po Box 238	Gaffney, SC 29342	864-838-0210 09/30/16
111791016	Stroupe, James W	Stroupes Backflows	181 Vienna Rd	Gaffney, SC 29340	864-490-3363 03/31/16
111152418	Wilkerson, Teddie E	Wilkerson Plumbing	214 Midway Terrace	Gaffney, SC 29341	864-487-5111 12/31/18

Total: 12

Chester

Cert No.	Name	Employer	Address	Phone	Expires
112067318	Caldwell, Robert P	C & C Plumbing	Po Box 929	Chester, SC 29706	803-377-1877 06/30/18
112286916	Jones, Patrick D	Performance Fire Protection	514 Saluda Rd	Chester, SC 29706	704-230-6506 03/31/16
112181418	Keen, Dennis W	D & D Irrigation	1066 Langley Dr	Chester, SC 29706	803-280-3460 09/30/18
112232818	Keen, Toni E	D & D Irrigation & Handyman Service	1066 Langley Dr	Chester, SC 29706	803-280-3460 09/30/18

Total: 4

Chesterfield

Cert No.	Name	Employer	Address	Phone	Expires
113236716	Adams, Delbert	Rivers Plumbing & Electric Inc	Po Box 647	Chesterfield, SC 29709	843-623-6520 03/31/16
113252218	Barrett, Damon C	Oliver Environmental Services	Po Box 291	Ruby, SC 29741	843-680-0815 06/30/18
113261718	Gainey, Elwood E	Gaineys Backflow Testing & Repair	151 Shaw Ln	Chesterfield, SC 29709	843-857-5293 09/30/18
113045819	Graves, Henry M	Graves Plumbing	1680 S Front St	Pageland, SC 29728	843-680-2011 03/31/19
113011918	Johnson, Johnnie T JR	Johnson Backflow Prevention	420 Beverly Dr	Cheraw, SC 29520	843-537-4230 09/30/18
113156017	Malloy, Richard T	Malloy Plumbing Service	7685 Teals Mill Rd	Cheraw, SC 29520	843-537-5065 06/30/17
113252118	Penny, Chasity E	Oliver Environmental Services	Po Box 291	Ruby, SC 29741	843-680-3411 06/30/18
113076716	Rivers, Randy J	Rivers Plumbing & Electric	Po Box 647	Chesterfield, SC 29709	843-623-6520 12/31/16

Total: 8

Clarendon

Cert No.	Name	Employer	Address	Phone	Expires
114242216	Hudson, Will C	Wright Way Plumbing	4005 Congruity Rd	Gable, SC 29051	803-406-4947 12/31/16
114206218	Strickland, David M	Water Works Backflow Testing & Re	1882 Camp Shelor Dr	Manning, SC 29102	803-478-8846 06/30/18
114107717	Wells, Glenn H JR	Aqua Backflow	Po Box 161	Manning, SC 29102	803-435-4112 09/30/17
114253218	Welsh, Helen P		17913 Hwy 301	Turbeville, SC 29162	843-659-8921 06/30/18

Total: 4

Colleton

Cert No.	Name	Employer	Address	Phone	Expires
115080917	Burgoon, Mark L	ML B Remodeling	8630 Sniders Hwy	Ruffin, SC 29475	843-562-6520 09/30/17
115143216	Frank, Johnny	Environmental Technology Solution	861 Quail Dr	Walterboro, SC 29488	843-538-6985 06/30/16
115233018	Stratton, Weston T	Best Plumbing Inc	105 Sidneys Rd	Walterboro, SC 29488	843-538-5147 12/31/18

Total: 3

Darlington

Cert No.	Name	Employer	Address	Phone	Expires
116006316	Anderson, Charles P JR	Anderson Plumbing & Irrigation	1337 Swift Creek Rd	Hartsville, SC 29550	843-332-5854 03/31/16
116258318	Ard, Richard F	Anderson Plumbing & Industrial Inc	Po Box 748	Hartsville, SC 29551	843-332-5854 06/30/18
116170716	Boykin, Eric A	Boykins Backflow Service	1124 New Market Rd	Hartsville, SC 29550	843-601-8996 12/31/16
116248817	Crowley, Chester A JR	Crowleys Plumbing Inc	137 E Old Camden Rd	Hartsville, SC 29550	843-332-2186 09/30/17
116070918	Henriksson, Lance H	Henriksson Enterprises	145 North St	Darlington, SC 29532	843-229-4966 12/31/18
116220817	Meadows, Gregory	Anderson Plumbing & Irrigation Inc	1337 Swift Creek Rd	Hartsville, SC 29550	843-332-5854 03/31/17
116104318	Smith, George R JR	Smith Landscaping	1556 Poplar Branch Ln	Hartsville, SC 29550	843-861-0166 03/31/18
116255918	Smith, Ray	Smith Landscaping & Construction	1556 Poplar Branch Ln	Hartsville, SC 29550	843-858-3988 06/30/18
116247317	Thomas, Jake J	Irish Plumber	318 W College Ave	Hartsville, SC 29550	843-861-9449 06/30/17
116203919	Weatherford, Chris	Weatherford Irrigation & Services	810 Simpson Ln	Hartsville, SC 29550	843-383-6231 03/31/19

Total: 10

Dillon

Cert No.	Name	Employer	Address	Phone	Expires
117257817	Caines, Billy W	Miller Plumbing & Electric	204 W Harrison St	Dillon, SC 29536	843-506-0084 09/30/17
117293118	Fore, Mickey H	M F Backflow Testing	Po Box 243	Hamer, SC 29547	843-992-6990 09/30/18
117122516	Jackson, Hardy L	Jackson'S Backflow Services	1715 Hwy 301 N	Dillon, SC 29536	843-774-5258 06/30/16
117150216	Jackson, Victor G	Vics Backflow Testing Services	3133 Burke Rd	Dillon, SC 29536	843-774-0859 06/30/16

Total: 4

Dorchester

Cert No.	Name	Employer	Address	Phone	Expires
118046818	Alexander, Henry S	Waterworks	199 Whispering Trail	Summerville, SC 29485	843-330-2124 09/30/18
118163718	Cornwell, Steven D	Cornwell Backflows	408 Brailsford Blvd	Summerville, SC 29485	843-729-3351 06/30/18
118227618	Davis, Tom	AR S / Rescue Rooter	102 Foxcroft Ln	Summerville, SC 29485	843-364-3043 06/30/18
118253518	Forsythe, Heather A	Cane Bay Backflow Testing	164 Lindera Preserve Blvd	Summerville, SC 29483	843-412-0214 03/31/18
118220417	Gazaille, Paul E		124 Old Tower Rd	Summerville, SC 29483	843-640-4404 06/30/17
118210016	Gralski, Anthony P	Certified Backflow	5268 Mulholland Dr	Summerville, SC 29485	843-518-7646 03/31/16
118071916	Green, Dennis H	Green Plumbing	Po Box 526	Ridgeville, SC 29472	843-830-6532 09/30/16
118262118	Greenhill, Chris M	Palmetto Landscaping	112 Macfarren Ln	Summerville, SC 29485	843-822-1142 12/31/18
118064616	Hoff, Lee D	Ashley River Backflow	100 Sawmill Dr	Summerville, SC 29483	843-871-5224 03/31/16
118265017	Hunt, Jack R	Affordable Backflow Services	116 Mendenhall St	Summerville, SC 29483	843-697-3886 03/31/17
118070718	Maynor, Robert A	Coastal Sprinkler Company Inc	111 Farm Rd	Summerville, SC 29485	843-209-7530 06/30/18
118082116	Mcdaniel, Jack V	Tri-County Backflow	1244 Orange Branch Rd	Charleston, SC 29407	843-571-3782 03/31/16
118244117	Mcdonald, Jennifer L	Melfi Plumbing Llc	117 Donna Dr	Summerville, SC 29483	843-801-0562 03/31/17
118244217	Melfi, Anthony T JR	Melfi Plumbing Llc	117 Donna Dr	Summerville, SC 29483	843-343-1651 03/31/17
118019117	Moorer, Charles C	Moorer Plumbing	Po Box 96	Reevesville, SC 29471	843-560-1160 03/31/17
118253418	Morris, David W	Backflows By Wayne	15041 Cottageville Hwy	Ridgeville, SC 29472	843-575-7857 06/30/18
118066317	Murdaugh, Richard D JR		436 Hill Branch Rd	Ridgeville, SC 29472	843-871-1590 03/31/17
118027816	Pennington, Bobby E JR	Winn Penn Plumbing Inc	121 Embassy Dr	Summerville, SC 29483	843-478-7413 12/31/16
118254218	Pennix, Timothy C	Adaptive Services	714 East 3rd North St	Summerville, SC 29485	843-574-3546 03/31/18
118240216	Pereira, Chris	C & P Backflow	8576 Kennestone Ln	N Charleston, SC 29420	843-813-1037 09/30/16
118157518	Priester, Michael E	Backflow Preventer Specialties	111 Tasker Dr	Summerville, SC 29485	843-873-6449 09/30/18
118219017	Rippee, Donald E	Cane Bay Backflow Testing	358 Oyster Bay Dr	Summerville, SC 29483	843-826-2641 03/31/17
118185717	Runyon, Rodney J	Palmetto Backflow	191 Rolling Meadows Dr	Summerville, SC 29485	843-821-6138 03/31/17
118267318	Sweatman, Daryl	Backflow Repair & Testing	135 Sweatman Ln	Summerville, SC 29483	843-817-9091 03/31/18
118273319	White, Stacy L	Ashley River Services Inc	100 Sawmill Dr	Summerville, SC 29483	843-214-0242 03/31/19
118148717	Williams, John	Backflow Preventer Specialties	8333 Longridge Rd	North Charleston, SC 29418	843-509-7098 09/30/17

Total: 26

Edgefield

Cert No.	Name	Employer	Address	Phone	Expires
119222317	Baker, Douglas W	Mr Rooter Of The C S R A	Po Box 146	Edgefield, SC 29824	855-206-6631 09/30/17

Total: 1

Florence

Cert No.	Name	Employer	Address	Phone	Expires
121177117	Atkinson, Scott	Jacob Plumbing	210 W Cedar St	843-667-0942	09/30/17
121140616	Bair, Joshua S	Bair Co Backflow Prevention	Po Box 12124	843-496-8899	09/30/16
121180916	Bigford, Kevin	Cayce Company	2710 S Irby St	843-662-0341	12/31/16
121191517	Carpenter, Dennis R	Ray Carpenter Plumbing	711 Kitty Ln	843-917-7603	12/31/17
121248717	Davis, Brent K	Viking Fire Protection	Po Box 5868	843-664-0077	09/30/17
121172716	Davis, Charles R	Davis & Brown	Po Box 15038	843-601-1684	03/31/16
121255618	Dayton, Michael	Cayce Mechanical Company	2710 S Irby St	843-662-0341	03/31/18
121225517	Finch, John J	Finch Backflow	1017 S Edisto Dr	843-601-0290	09/30/17
121029418	Floyd, Terry E	S & T Water Utilities	Po Box 154	843-687-8760	06/30/18
121253818	Gnip, Edward J	International Fire Protection	2724 W Palmetto St Ste 5	843-536-8080	03/31/18
121102517	Hunter, David F	D Frankie Hunter	370 Byrnes Cir	843-386-9134	06/30/17
121017317	Jacob, Ulrich P	Ulrich Enterprises	2133 Twin Bridge Dr	843-245-7698	06/30/17
121069416	Jordan, Anthony J	Jordan & Sons Plumbing	2200 W Jody Rd	843-669-4505	03/31/16
121079717	Ketelsen, Gary A	Viking Fire Protection	Po Box 5868	843-664-0077	09/30/17
121081116	Kirby, Jeffrey L	Jeffrey Kirby	3828 Savannah Grove Rd	843-662-4829	09/30/16
121711216	Knotts, Thomas R	Urquhart Plumbing	Po Box 12063	843-662-2571	09/30/16
121371216	Lee, Joel	Joel E Lee	209 Honeysuckle Ln	843-206-8333	09/30/16
121253118	Mcdaniel, James	Mcdaniel Plumbing Company Inc	122 Branford Rd	843-453-3080	06/30/18
121192917	Mckenzie, Kevin J	Viking Fire Protection	Po Box 5868	843-664-0077	09/30/17
121006218	Mckissick, Paul K	Paul Mckissick	Po Box 292	843-250-1262	06/30/18
121033816	Miller, Richard L JR	City Plumbing Company	933 Santiago Dr	843-662-2365	12/31/16
121173218	Moore, Clifton W	S & T Utilities	Po Box 154	843-372-3569	06/30/18
121025617	Ricks, Jody	Davis & Brown	Po Box 15038	843-601-2796	09/30/17
121255018	Robinson, Rex E	Cayce Mechanical Company	2710 S Irby St	843-662-0341	03/31/18
121271719	Seiss, Fred	Jacob Plumbing Company Inc	210 W Cedar St	843-667-0942	03/31/19
121170316	Smith, Scott A	A-1 Designs & Builders Llc	Po Box 4396	843-858-1940	03/31/16
121197018	Stokes, Wesley A	Stokes Plumbing	4628 Moore Rd	843-687-2696	09/30/18
121026716	Urquhart, Thomas K	Urquhart Plumbing	Po Box 12063	843-662-2571	09/30/16
121246117	Welch, Joshua H	S & T Utilities	Po Box 154	843-687-8760	06/30/17

Total: 29

Georgetown

Cert No.	Name	Employer	Address	Phone	Expires
122246717	Burkett, John G	R C Jacobs	Po Box 2836	843-527-2404	06/30/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 13 of 38

Cert No.	Name	Employer	Address	Phone	Expires
122243416	Coleman, James B JR	D I Wilson Company Inc	Po Box 1382	843-527-2707	12/31/16
122259418	Dorr, Michael	J M J Plumbing	9751 Moose Rd Ste 3	843-651-1080	06/30/18
122217117	Gailey, Ray T	R C Jacobs Inc	Po Box 2836	843-527-2404	03/31/17
122247017	Harrell, Chad E	R C Jacobs	Po Box 2836	843-527-2404	06/30/17
122217217	Jacobs, Casey W	R C Jacobs Inc	Po Box 2836	843-527-2404	03/31/17
122087316	Long, Randy W	Grand Strand Fire Sprinkler	2410 Hwy 17 S Business	843-651-9825	03/31/16
122252518	Mccants, Brandon M	Perfection Landscaping Inc	Po Box 1207	843-455-0482	06/30/18
122792116	Mcfarland, William B	J M J Plumbing	9751 Moose Rd Unit 3	843-651-1080	09/30/16
122236316	Owens, Eric A	Indigo Landscaping & Construction	Po Box 3153	843-235-0824	03/31/16
122236616	Starr, Courtenay	Grand Strand Fire Sprinkler	2410 Hwy 17 S Business	843-651-9825	03/31/16
122236216	Steuer, Robert N	Indigo Landscaping & Construction	Po Box 3153	843-235-0824	03/31/16
122259018	Thompson, Cary L	C R M Of The Carolinas	Po Box 3351	843-491-1566	06/30/18

Total: 13

Greenville

Cert No.	Name	Employer	Address	Phone	Expires
123138217	Allen, Richard C	Batsons Plumbing	Po Box 695	864-297-6688	06/30/17
123111918	Amick, Randall C	Amick Plumbing	148 Holcombe Rd	864-567-4439	06/30/18
123258518	Ashley, Corey J	Harvey & Associates Inc	Po Box 818	864-862-2379	06/30/18
123091017	Bagwell, Charles P	AI'S Plumbing	Po Box 8339	864-304-8220	12/31/17
123208218	Baldwin, Tim W	P & L Mechanical	720 Wade Hampton Blvd	864-877-8389	12/31/18
123140017	Banks, Clyde	D & C Backflow	129 Oak Hill Dr	864-294-1619	12/31/17
123179116	Barton, Jeffrey C	Aarons Plumbing	105 Glades Ct	864-268-1107	06/30/16
123138617	Bays, Brad	Prolawn Services	Po Box 3604	864-423-5578	03/31/17
123165318	Beggs, Randy A	Sentry Sprinkler Service Inc	Po Box 947	864-286-9835	06/30/18
123056918	Bell, Eric D	London Rain Irrigation	2502 Brushy Creek Rd	864-244-9990	09/30/18
123252718	Bellew, David E	Harvey & Associates Inc	Po Box 818	864-862-2379	06/30/18
123131016	Bellew, Michael J	M S S Fire & Security Llc	1120 W Butler Rd Ste G	864-385-9701	06/30/16
123054916	Bennett, Michael D	Harvey & Associates	Po Box 818	864-862-2379	03/31/16
123263518	Bishop, Scott W	A & W Plumbing	Po Box 436	864-845-9447	12/31/18
123260818	Black, Joseph R	Sentry Sprinkler Service Inc	Po Box 947	864-286-9835	09/30/18
123249517	Bolta, Carlos D	Dipple Plumbing Inc	211 N Pleasantburg Dr	864-271-1205	09/30/17
123036317	Bowhall, Robert E	A & W Plumbing	Po Box 436	864-444-7136	12/31/17
123247917	Brackett, Robert L	American Fire Protection Inc	Po Box 4139	864-250-2001	09/30/17
123147717	Brock, Barry J	Long & Sons Utility	Po Box 578	864-967-2813	12/31/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 14 of 38

Cert No.	Name	Employer	Address		Phone	Expires
123261118	Brown, Daniel	Roto-Rooter	145-A Verdin Rd	Greenville, SC 29607	864-288-7686	09/30/18
123142217	Brown, Rex A	Commercial Industrial Plumbing Inc	Po Box 8008	Greenville, SC 29604	864-905-7182	09/30/17
123222417	Brown, Thomas G	American Fire Protection Inc	Po Box 4139	Greenville, SC 29608	864-250-2001	06/30/17
123792716	Brownlee, Gregory S	Gooch Mechanical	345 E Standing Springs Rd	Simpsonville, SC 29680	864-963-8268	12/31/16
123282318	Burnett, Curtiss D	T R Valve & Water	204 Ansley Dr	Simpsonville, SC 29681	864-297-8195	06/30/18
123254818	Burton, Phillip J	Burtons All Season Landscaping	101 Hartman Rd	Greer, SC 29651	864-378-2932	03/31/18
123248117	Busche, Chad	Dipple Plumbing Inc	211 N Pleasantburg Dr	Greenville, SC 29607	864-271-1205	09/30/17
123137018	Campbell, Derek T	Sentry Sprinkler Service Inc	Po Box 947	Mauldin, SC 29662	864-286-9835	06/30/18
123239516	Campbell, Paul	Mr Rooter Of Greenville	10 Woods Lake Rd	Greenville, SC 29607	864-567-2107	09/30/16
123229218	Carson, Jesse	Kens Plumbing Inc	Po Box 3769	Greenville, SC 29608	864-787-4640	06/30/18
123055016	Carter, James R	Harvey & Associates	Po Box 818	Fountain Inn, SC 29644	864-862-2379	03/31/16
123149218	Charron, Kenneth R	Irrigation Repair & Backflow Services	Po Box 51146	Piedmont, SC 29673	864-444-2066	03/31/18
123245117	Childers, Jonathan B	Brickman Group	3086 Hwy 101 S	Greer, SC 29651	864-934-6432	03/31/17
123096216	Chitwood, Larry A	United Utility Companies Inc	3334 W Georgia Rd	Piedmont, SC 29673	864-909-2684	06/30/16
123022217	Clark, Richard N	Premier Fire Protection	4 New Dunham Bridge Rd	Greenville, SC 29617	864-295-0050	03/31/17
123243816	Clement, Blain	Benjamin Franklin Plumbing	3307 New Easley Hwy	Greenville, SC 29611	864-269-5688	12/31/16
123261518	Coley, Shawn C	Benjamin Franklin Plumbing	3307 New Easley Hwy	Greenville, SC 29611	864-269-5688	09/30/18
123261018	Connolly, Kevin P	Benjamin Franklin Plumbing	3307 New Easley Hwy	Greenville, SC 29611	864-269-5688	09/30/18
123067017	Cox, James L	Lamar Cox	107 Cravens Creek Ct	Piedmont, SC 29673	864-706-5596	06/30/17
123010816	Cromer, Robert G	Harvey & Associates Inc	Po Box 818	Fountain Inn, SC 29644	864-862-2379	06/30/16
123240016	Davis, Ellis	G & G Construction	Po Box 36	Fountain Inn, SC 29644	864-862-3501	09/30/16
123222817	Dean, Christopher D	Roto Rooter	145-A Verdin Rd	Greenville, SC 29607	864-288-7686	09/30/17
123252418	Dixon, Russ E	Mr Rooter Of Greenville	10 Woods Lake Rd	Greenville, SC 29607	864-220-1414	06/30/18
123204317	Edwards, Charlie D	Carolina Automatic Sprinkler	Po Box 157	Mauldin, SC 29662	864-963-3436	06/30/17
123215916	Epps, Christopher B		25 Lavonia Ave	Greenville, SC 29609	864-304-3123	12/31/16
123121418	Fisher, Jonathan M	Greenville Backflow	19 Buckingham Rd	Greenville, SC 29607	864-399-2209	06/30/18
123232118	Fortescue, Calvin J	Corley Plumbing Heating & Air	300 Ben Hamby Dr	Greenville, SC 29615	864-288-9733	06/30/18
123162418	Fowler, Will B	A-1 Backflow	1834 Fairview Rd	Fountain Inn, SC 29644	864-304-6134	03/31/18
123196018	Freeman, Bryan J	Thomas Brothers Nursery & Landsc	5104 Old Augusta Rd	Greenville, SC 29605	864-299-3789	12/31/18
123183118	Gast, John A	All Clear Plumbing	101 Greenlake Rd	Greenville, SC 29607	864-979-7059	06/30/18
123143117	Giese, Larry L	The Repair Doctor	2 Fenland Dr	Greenville, SC 29615	864-275-2797	06/30/17
123255118	Gilliland, Leonard B	Harvey & Associates Inc	Po Box 818	Fountain Inn, SC 29644	864-862-2379	03/31/18
123057916	Ginn, Jonathan	Benjamin Franklin Plumbing	3307 New Easley Hwy	Greenville, SC 29611	864-269-5520	12/31/16
123156917	Glenn, Christopher A	Forever Green Irrigation	902 Half Mile Way	Greenville, SC 29609	864-268-2108	12/31/17
123116317	Goldsmith, Todd K	Liquid Systems Inc	998 N Maple St	Simpsonville, SC 29681	864-967-4567	03/31/17
123263318	Gooch, Matthew T	Gooch Mechanical Contractors Inc	345 E Standing Springs Rd	Simpsonville, SC 29680	864-963-8268	12/31/18

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 15 of 38

Cert No.	Name	Employer	Address	Phone	Expires
123248217	Gravely, Michael F	C H Patrick & Company Inc	1806 Perimeter Rd	864-277-8977	09/30/17
123183216	Greer, Paul B	Harvey & Associates Inc	306 Hughes St	864-862-2379	12/31/16
123249417	Greer, Quinton	Roto-Rooter	145-A Verdin Rd	864-288-7686	09/30/17
123106718	Hall, Robert W	Robert Hall Plumbing	Po Box 1155	864-246-8629	03/31/18
123033117	Harbert, Robert E	Bobby'S Backflow Testing	116 Smith Ct	864-630-5128	06/30/17
123191917	Harvey, David M	Harvey & Associates Inc	Po Box 818	864-862-2379	12/31/17
123056716	Harvey, David N	Harvey & Associates Inc	Po Box 818	864-862-2379	12/31/16
123010916	Harvey, Jeffrey G	Harvey & Associates Inc	Po Box 818	864-862-2379	06/30/16
123157417	Hawkins, Steven C	Living Water Irrigation	100 Twinflower Dr	864-901-2118	06/30/17
123142617	Haynes, Michael A	All Green Irrigation	114 Raintree Dr	803-728-9000	06/30/17
123264916	Helms, Tony D	Cintas Fire Protection	1 Marcus Dr Ste 204	864-551-6023	12/31/16
123260718	Hipp, David B	Sentry Sprinkler Service Inc	Po Box 947	864-286-9835	09/30/18
123078917	Ivey, James D	Batsons Plumbing	Po Box 695	864-297-6688	06/30/17
123258918	Jewell, Danny	Bob Miller Plumbing	Po Box 926	864-787-2888	06/30/18
123229318	Kaiser, Thomas J	All About Irrigation	116 Monarch Pl	864-325-7060	09/30/18
123204518	Keller, Mike B	Five Star Plumbing Heating & Coolin	3385 Brushy Creek Rd	864-517-2697	06/30/18
123233718	Kimbrell, David M	Kimbrells Plumbing	2 Kilgore St	864-787-4312	06/30/18
123101616	Kimbrell, Larry D	L D Kimbrell Plumbing	2 Kilgor St	864-346-7220	09/30/16
123229518	Lamb, Michael C	Brothers Plumbing & Air	107 Sunbelt Ct	864-277-2111	06/30/18
123251017	Lawrence, Luther R	A & A Fire Protection	Po Box 709	864-859-9700	12/31/17
123217416	Leopard, Jim H	Harvey & Associates Inc	Po Box 818	864-862-2379	12/31/16
123225217	Long, Adam T	Long & Sons Utility	Po Box 727	864-967-2813	12/31/17
123150317	Long, Lee D	Long & Sons Utility	109 Rosa Ln	864-967-2813	12/31/17
123034518	Malone, Michael J	Malone Plumbing	2801 Wade Hampton Blvd St	864-304-3659	06/30/18
123040617	Manley, Billy R	Carolina Automatic Sprinkler	Taylors, SC 29687 Po Box 157	864-963-3436	06/30/17
123132217	Marcus, Darlene	Blue Ridge Backflow	Mauldin, SC 29662 149 Neely Mill Rd	864-430-7643	06/30/17
123134417	Marcus, Joe H SR	Blue Ridge Backflow	Greer, SC 29651 149 Neely Mill Rd	864-895-5306	03/31/17
123044617	Marcus, Joey H	Blue Ridge Backflow	Greer, SC 29651 149 Neely Mill Rd	864-430-7644	12/31/17
123193918	Martin, David S	A-1 Backflow	Fountain Inn, SC 29644 1834 Fairview Rd	864-862-6400	03/31/18
123040317	Mauney, Brian J	Greenville Irrigation Llc	Taylor, SC 29687 5014 Edwards Rd	864-414-2613	12/31/17
123170817	Mccameron, Christopher	Carolina Automatic Sprinkler	Mauldin, SC 29662 Po Box 157	864-963-3436	06/30/17
123016916	Mccrary, Ernest F	A & A Fire Protection	Mauldin, SC 29662 Po Box 709	864-859-9700	12/31/16
123151516	Mckittrick, Ben E	Ben'S Backflow Testing & Repair	Fountain Inn, SC 29644 19 Harmony Cir	864-862-6585	03/31/16
123263018	Mckittrick, Kevin R	Bens Backflow Testing And Repair	Fountain Inn, SC 29644 19 Harmony Cir	864-238-5277	12/31/18
123150617	Mckittrick, Kyle B	Ben'S Backflow Testing & Repair	Fountain Inn, SC 29644 19 Harmony Cir	864-238-5277	12/31/17
123166016	Mitchell, Robert L	The Spinx Company	Greenville, SC 29607 1414 E Washington St	864-444-5884	09/30/16

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 16 of 38

Cert No.	Name	Employer	Address	Phone	Expires
123261218	Moats, Chris	Roto-Rooter	145-A Verdin Rd	864-288-7686	09/30/18
123243616	Moody, Derrick S	A & A Fire Protection	Po Box 709	864-859-9700	12/31/16
123115118	Motsinger, Robert L	Alpha Engineering Services Inc	301 Silver Creek Rd	864-292-9537	03/31/18
123137716	Mullinax, David E	Economy Backflow	306 Holly Rd	864-361-0423	09/30/16
123217516	Neff, Mark A	American Fire Protection Inc	Po Box 4139	864-250-2001	09/30/16
123257218	Niemiec, Michael J	General Fire Safety	5409 Augusta Rd	864-299-8979	06/30/18
123057418	Nixon, Stephen M	London Rain Irrigation	2502 Brushy Creek Rd	864-244-9990	09/30/18
123229418	Parker, Ronald E	American Fire Protection Inc	70 Worley Rd	864-250-2001	06/30/18
123015817	Patterson, Joey B		9 Old Rockhouse Rd	864-505-0901	09/30/17
123116418	Paxton, John T	John T Paxton	227 Mccarson Rd	864-836-8605	06/30/18
123252818	Payne, William G	Harvey & Associates Inc	Po Box 818	864-862-2379	06/30/18
123257918	Poole, Adam	Dipple Plumbing Inc	211 N Pleasantburg Dr	864-271-1205	06/30/18
123148817	Pruitt, Roger D	Foothills Maintenance Solutions	107 Tall Birch Dr	864-834-1024	06/30/17
123204618	Ramsey, Billy L	Roto-Rooter	145a Verdin Rd	864-288-7686	09/30/18
123095916	Randall, Tom	A & R Plumbing	111 Carr Rd	864-444-5562	09/30/16
123157216	Ravan, William G	Ravan Plumbing Company Inc	Po Box 14820	864-271-9460	09/30/16
123058216	Ray, Edward A	Advanced Fire Protection Inc	Po Box 580	864-834-5188	03/31/16
123213716	Reddy, James T	Cintas Fire Protection	1 Marcus Dr Ste 204	864-661-1020	06/30/16
123262918	Rhodes, Grant T	Mr Rooter Plumbing	10 Woods Lake Rd	864-220-1414	12/31/18
123264816	Roddy, Joshua K	Cintas Fire Protection	1 Marcus Dr Ste 204	864-661-1020	12/31/16
123159417	Rogers, Michael W	American Fire Protection	Po Box 4139	864-250-2001	06/30/17
123211416	Sanders, William M	A & A Fire Protection	Po Box 709	864-859-9700	06/30/16
123184617	Scheidly, Darin D	AA Backflow Test	201 W Butler Rd #261	864-567-6940	03/31/17
123158618	Schwalm, Eric L	H 2 O Backflow Inc	107 Stone Creek Rd	864-918-6543	06/30/18
123058416	Scott, Dewayne	Advanced Fire Protection Inc	Po Box 580	864-834-5188	03/31/16
123247817	Seymore, Michael D	G S Plumbing Inc	55-A Donkle Rd	864-268-7394	09/30/17
123261418	Share, Jack W	Five Star Plumbing Heating & Coolin	3385 Brushy Creek Rd	864-770-8000	09/30/18
123205518	Sharpe, Charles W	Sharpe Controls & Service Llc	310 Wembley Rd	864-915-5963	09/30/18
123159118	Shaw, James R	American Fire Protection	720 Worley Rd	864-250-2001	06/30/18
123053518	Sheriff, Willis P	Huff Piping Inc	Po Box 14003	864-246-2684	06/30/18
123041317	Skelton, Thomas C	Turfmaster	Po Box 25636	864-430-0117	12/31/17
123134716	Smith, Winfield S	All Clear Plumbing	101 Green Lake Rd	864-979-7059	06/30/16
123192617	Soltis, Michael A	Backflow Testing & Repair	103 Woodtrail Ct	864-399-8507	09/30/17
123240316	Spongberg, Lukas H	Jennings-Dill Inc	33 Grand Ave	864-235-2518	09/30/16
123258018	Stancil, James R	Harvey & Associates Inc	Po Box 818	864-862-2379	06/30/18
123245517	Stanley, Albert L	Mccall Residential Services	1115 Enclave Paris Dr	864-354-7058	03/31/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 17 of 38

Cert No.	Name	Employer	Address	Phone	Expires
123072717	Stepp, Mark A	Marks Plumbing	Po Box 4134	864-414-7902	12/31/17
123118517	Sutton, George R JR	American Water Works	517 Wembley Rd	864-325-3908	06/30/17
123217316	Taylor, Michael R	Harvey & Associates Inc	Po Box 818	864-862-2379	12/31/16
123246917	Thomas, Samuel M	Thomas Brothers Nursery & Landsc	5104 Old Augusta Rd	864-299-3789	06/30/17
123185217	Thompson, Richard	Backflow Of Simpsonville	802 Willow Branch Dr	864-906-8927	06/30/17
123270918	Tolbert, Shelby R	T R Valve & Water	255 Cunningham Rd	864-313-1006	06/30/18
123112217	Trotter, Gary L	Water Flow Systems Inc	Po Box 313	864-288-9950	12/31/17
123229618	Vaughn, Robert J	American Fire Protection Inc	720 Worley Rd	864-250-2001	06/30/18
123023918	Wade, Craig R	Beck Plumbing	311 Morrow St	864-877-2711	09/30/18
123268417	Walker, John D	Oxner Landscape & Irrigation	Po Box 9216	864-270-7769	06/30/17
123107116	Walters, Shane E	Shane Walters	5553 Locust Hill Rd	864-505-4445	09/30/16
123134016	Ward, David L	A & A Fire Protection	Po Box 709	864-859-9700	06/30/16
123081718	Warren, Josh L	B & L Mechanical Inc	Po Box 6682	864-277-5487	03/31/18
123232518	Weber, John	Roto-Rooter	145-A Verdin Rd	864-288-7686	09/30/18
123263618	Wham, Dustin S	Carolina Automatic Sprinkler	Po Box 157	864-963-3436	12/31/18
123248417	White, William A	Five Star Plumbing Heating & Coolin	3385 Brushy Creek Rd	864-770-8000	09/30/17
123134816	Whiten, David G	Crown Plumbing Llc	Po Box 1137	864-244-3553	06/30/16
123142517	Wiggs, Larry	Sprinkler Tek	3 Confederate Cir	864-350-7771	03/31/17
123252917	Williams, James D	D & C Backflow	129 Oak Hill Dr	864-294-1619	12/31/17
123262818	Wilson, Josh	Carolina Automatic Sprinkler	Po Box 157	864-963-3436	12/31/18
123015717	Yonce, Joseph L	Cintas Fire Protection	1 Marcus Dr Ste 204	864-661-1020	03/31/17

Total: 148

Greenwood

Cert No.	Name	Employer	Address	Phone	Expires
124024318	Anderson, Edmund F	E F Anderson Company	Po Box 1005	864-942-2537	06/30/18
124249617	Balentine, Daniel M	Blacks Trenching & Plumbing	6705 Hwy 246 S	864-993-4802	09/30/17
124147317	Black, Tony W	Blacks Trenching & Plumbing	1114 Hwy 248 S	864-389-0671	09/30/17
124073616	Boyer, Richard L	Piedmont Fire Extinguishers	72 Smith Village Rd	864-677-3674	12/31/16
124133816	Clinemyer, Charles R JR	C & B Backflows	7011 Hwy 178 N	864-456-9976	06/30/16
124261318	Coker, David E	Mathis Plumbing & Heating Compar	Po Box 716	864-377-4771	09/30/18
124138016	Davenport, David B	Davenport Plumbing	2509 Cokesbury Rd	864-229-2202	12/31/16
124061516	Jay, Robert M	Dazzle Carwash Corporation	1516a Bypass 72 Ne	864-992-8217	03/31/16
124063817	Jones, Todd A	Mathis Plumbing Heating & Air	Po Box 716	864-229-7117	12/31/17
124173416	Mathis, Tyler W	Mathis Plumbing & Heating Inc	Po Box 716	864-229-7117	09/30/16

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 18 of 38

Cert No.	Name	Employer	Address	Phone	Expires
124245017	Mcalister, Julian R	Rob Mcalister Enterprises Llc	1105 Reedy Cr Rd	Bradley, SC 29819	864-554-0552 03/31/17
124147417	Roark, David K	Blacks Trenching & Plumbing	107 Pinehaven Dr	Ninety Six, SC 29666	864-980-4176 12/31/17
124791616	Sweatt, David M	C & B Backflows	7011 Hwy 178 N	Donalds, SC 29638	864-993-5162 06/30/16
124041117	Williamson, Tony	L & L Environmental	Po Box 359	Ware Shoals, SC 29692	864-456-2696 12/31/17

Total: 14

Hampton

Cert No.	Name	Employer	Address	Phone	Expires
125156517	Oberholtzer, Bret A	Many MS	17 Salkehatchie Rd	Yemassee, SC 29945	843-321-0442 06/30/17
Total: 1					

Horry

Cert No.	Name	Employer	Address	Phone	Expires
126160618	Baker, Harold O JR	C L Benton & Sons Inc	706 38th Ave N	Myrtle Beach, SC 29577	843-448-3116 03/31/18
126219217	Baker, Jonathan M	Bullard Plumbing	Po Box 1938	Conway, SC 29528	843-458-1411 06/30/17
126271619	Baker, Rebecca L	Bullard Plumbing	Po Box 1938	Conway, SC 29528	843-347-6085 03/31/19
126170419	Baldwin, Richard J	R A S K Plumbing Inc	3067 Bayhaven Dr	Myrtle Beach, SC 29579	843-241-7366 03/31/19
126246017	Black, Dennis L	Carolina Cool Inc	1294 Surfside Industrial ParkSurfside Beach, SC 29575	843-238-5805 06/30/17	
126145218	Blackmon, Richard L	Coastal Contract Services	1405 Mr Joe White Ave Ste 1 Myrtle Beach, SC 29577	843-241-2167 03/31/18	
126255418	Blankenship, Kevin A	V S C Fire & Security Inc	1306-A Enterprise Ave	Myrtle Beach, SC 29577	843-443-3260 03/31/18
126083418	Blum, David A	Sun Pro Enterprise	Po Box 2276	Conway, SC 29528	843-457-5055 03/31/18
126063516	Booth, James D IV	J D B Services	1913 Booth Rd	Loris, SC 29569	843-716-5021 09/30/16
126038217	Boyers, James G	James Plumbing Company Inc	Po Box 4065	N Myrtle Beach, SC 29597	843-249-2685 06/30/17
126182216	Breeden, Charles	Coastal Contracting Services	1405 Mr Joe White Ave Ste 1 Myrtle Beach, SC 29577	910-209-1113 06/30/16	
126246617	Bromley, Shaun G	Pye Barker Fire Safety	3656 Clay Pond Rd	Myrtle Beach, SC 29579	843-903-7277 06/30/17
126160117	Buchanan, Billy G	Carolina Cool	1294 Surfside Industrial ParkSurfside Beach, SC 29575	843-458-3096 06/30/17	
126160018	Busch, John G	Carolina Cooling & Plumbing Inc	1294 Surfside Industrial ParkSurfside Beach, SC 29575	843-238-5805 09/30/18	
126117018	Causey, Craig A	Craig Causey Plumbing Llc	Po Box 201	Conway, SC 29528	843-458-4715 09/30/18
126231318	Chaky, John P	C R M Services	3738 Wesley St Ste A	Myrtle Beach, SC 29579	843-902-9535 12/31/18
126177316	Clem, Nicholas B	Clem'S Lawn Service Llc	1718 Holly Ridge Dr	Longs, SC 29568	843-222-5672 03/31/16
126073816	Clubb, William W	Rainbow Irrigation	94 Ranchette Cir	Myrtle Beach, SC 29588	843-293-4931 03/31/16
126246517	Cohen, Scott	Carolina Cool Inc	1294 Surfside Industrial ParkSurfside Beach, SC 29575	843-238-5805 06/30/17	
126254918	Davidson, Patrick B	V S C Fire & Security Inc	1306 A Enterprise Ave	Myrtle Beach, SC 29577	843-443-3260 03/31/18
126794617	Doyle, Douglas L		2895 Society Dr	Conway, SC 29527	843-397-5498 06/30/17
126285217	Dudley, Ted S	Dudley Backflow Services	2031 Hwy 129	Galivants Ferry, SC 29544	843-855-7681 06/30/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16

Page 19 of 38

Cert No.	Name	Employer	Address	Phone	Expires
126255818	Feasel, Jason	Cayce Company Inc	Po Box 3067	Myrtle Beach, SC 29578-3067	843-448-9220 03/31/18
126028418	Fortson, Robert G	Environmental Systems Testing Ser	600 Hwy 544	Conway, SC 29526	843-347-7688 09/30/18
126241016	Gambal, Joseph F	Coastal Contract Services	1405 Mr Joe White Ave Ste #1	Myrtle Beach, SC 29577	843-241-2167 09/30/16
126036717	Gatling, Kim B	Atlantic Plumbing Company Inc	1347 Enterprise Ave	Myrtle Beach, SC 29577	843-448-5341 06/30/17
126253018	Gavrilis, Mike N	Usa Plumbing Llc	Po Box 50131	Myrtle Beach, SC 29579	843-241-8054 06/30/18
126181916	Gerber, Philip	Coastal Contract Services Llc	1405 Mr Joe White Ave Ste #1	Myrtle Beach, SC 29577	843-241-2167 06/30/16
126221217	Graham, Kenneth W	G & G Mining Company	Po Box 275	Aynor, SC 29511-0275	843-397-3381 06/30/17
126259118	Hagan, Steven P	Starwood Of Myrtle Beach Inc	226 Bush Dr	Myrtle Beach, SC 29579	843-236-4000 06/30/18
126211016	Hewitt, David J	9-1-1 Plumbing	284 Fox Catcher Dr	Myrtle Beach, SC 29588	843-712-1911 06/30/16
126220117	Holden, Bryan M	Myrtle Beach Fire Safety Group	1445 Cannon Rd	Myrtle Beach, SC 29577	843-839-0871 03/31/17
126246417	Holland, James A	V S C Fire & Security Inc	1306-A Enterprise Ave	Myrtle Beach, SC 29577	843-443-3260 06/30/17
126098117	Holmes, Jason L	Super Plumber Llc	Po Box 2247	Conway, SC 29528	843-254-5457 06/30/17
126176116	Hunter, Erik A	Mancill Inc	3201 Mr Joe White Ave	Myrtle Beach, SC 29577	843-448-1489 03/31/16
126272819	Iurilli, Thomas J	Mancill Inc	3201 Mr Joe White Ave	Myrtle Beach, SC 29577	843-448-1489 03/31/19
126245317	Korros, Seth M	Capital Irrigation Inc	Po Box 2491	Myrtle Beach, SC 29578	843-446-2382 03/31/17
126197918	Lee, Alan L	C L Benton & Sons Inc	706 38th Ave N	Myrtle Beach, SC 29577	843-448-3116 12/31/18
126105617	Lewis, William A		Po Box 2148	Conway, SC 29528	843-251-5545 06/30/17
126259518	Marks, John A	Action Plumbing Inc	Po Box 14008	Myrtle Beach, SC 29587	843-458-3951 09/30/18
126246217	Marrero, Jose M	V S C Fire & Security Inc	1306-A Enterprise Ave	Myrtle Beach, SC 29577	843-443-3260 06/30/17
126048316	Marro, Donald	Four Star Plumbing & Air	2385 Hwy 544	Conway, SC 29526	843-236-7142 09/30/16
126212816	Mather, David N	4-A Fire Protection Inc	801 66 Ave N Unit 2	Myrtle Beach, SC 29572	843-457-1866 09/30/16
126017617	Mattice, Linda L	Rainbow Irrigation	94 Ranchette Cir	Myrtle Beach, SC 29588	843-997-7576 06/30/17
126224117	Mcgirt, Joseph A	Simplex Grinnell	1578 Dividend Loop	Myrtle Beach, SC 29577	843-200-1298 09/30/17
126230518	Mendoza, Damien K	Myrtle Beach Fire Safety Group	1445 Cannon Rd	Myrtle Beach, SC 29577	843-916-8787 06/30/18
126087017	Mishoe, Rufus M	Four Star Plumbing & Air	2385 Hwy 544	Conway, SC 29526	843-236-7142 06/30/17
126272219	Mohney, Richard A	Pye Barker Fire & Safety	3656 Claypond Rd	Myrtle Beach, SC 29579	843-903-7277 03/31/19
126236916	Owens, Christopher L	C O Backflow Testing	Po Box 184	Aynor, SC 29511	843-344-5465 03/31/16
126174217	Parker, Joseph G	Gary Parker	2186 Sherwood Dr	Aynor, SC 29511	843-358-6740 06/30/17
126249317	Pedrick, Brian E	International Fire Protection	144 Somerworth Cir	Surfside Beach, SC 29575	843-536-8080 09/30/17
126224217	Perras, John M	Simplex Grinnell	1578 Dividend Loop	Myrtle Beach, SC 29577	843-286-8263 09/30/17
126198118	Pollin, Russell	Starwood Of Myrtle Beach Inc	226 Bush Dr	Myrtle Beach, SC 29579	843-236-4000 03/31/18
126236416	Powell, Ronald M	Myrtle Beach Fire Safety Group	1445 Cannon Rd	Myrtle Beach, SC 29577	843-916-8787 03/31/16
126259218	Pridemore, Lonnie W	Starwood Of Myrtle Beach Inc	226 Bush Dr	Myrtle Beach, SC 29579	843-236-4000 06/30/18
126160218	Rabon, Buddy	Buddy Rabon Plumbing Inc	Po Box 739	Myrtle Beach, SC 29578	843-385-1713 03/31/18
126241216	Richey, Douglas J	Myrtle Beach Fire Safety Group	1445 Cannon Rd	Myrtle Beach, SC 29577	843-916-8787 09/30/16
126245917	Riggs, Joseph W	Myrtle Beach Fire Safety Group	1445 Cannon Rd	Myrtle Beach, SC 29577	843-916-8787 06/30/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 20 of 38

Cert No.	Name	Employer	Address	Phone	Expires
126076017	Robinson, Richard E	Chase Plumbing Service Inc	Po Box 704	Little River, SC 29566	843-399-4250 06/30/17
126236816	Schaeffer, Steven M	Four Star Plumbing & Air Conditionir	2385 Hwy 544	Conway, SC 29526	843-236-7142 03/31/16
126797118	Sherrill, Otis W	Sherrills Backflow Testing	1058 Sea Mountain Hwy 9 - 2North Myrtle Beach, SC 29582		843-249-8456 06/30/18
126243316	Smith, Joseph A	Billys Plumbing Company Llc	Po Box 1051	Conway, SC 29528	843-234-0123 12/31/16
126271419	Spurlock, Jeffrey A	Mancill Inc	3201 Mr Joe White Ave	Myrtle Beach, SC 29577	843-448-1489 03/31/19
126213216	Stone, Phillip R	V S C Fire & Security	1306-A Enterprise Ave	Myrtle Beach, SC 29577	843-503-6081 09/30/16
126176017	Strickland, Marshall	Mancill Electric & Plumbing	3201 Mr Joe White Ave	Myrtle Beach, SC 29577	843-321-5714 03/31/17
126038418	Sullivan, Christopher W S	Sullivan Irrigation	5868 Friendship Ln	Myrtle Beach, SC 29588	843-215-6532 03/31/18
126142117	Sullivan, Kelly	Sullivan Irrigation	5868 Friendship Ln	Myrtle Beach, SC 29588	843-340-8742 06/30/17
126231018	Thurston, Charles K	Myrtle Beach Fire Safety Group	1445 Cannon Rd	Myrtle Beach, SC 29577	843-916-8787 09/30/18
126209516	Tollefson, Richard K	American Residential Services	1221 Harbour Towne Dr	Myrtle Beach, SC 29577	843-293-9999 09/30/16
126109818	Tricomi, Joseph E		2551 Lake Vista Dr	Little River, SC 29566	843-280-5300 03/31/18
126230118	Walters, Karl	The Noble Company	1125 48th Ave N	Myrtle Beach, SC 29575	843-449-6625 06/30/18
126016516	Ward, Robert K	V S C Fire & Security Inc	1306-A Enterprise Ave	Myrtle Beach, SC 29577	843-443-3260 03/31/16
126212917	Wright, Adam D	Oasis Landscapes & Irrigation Llc	Po Box 1567	Little River, SC 29566	843-280-0508 06/30/17
126237016	Wright, John A	A H S C Inc	209 Waltrip St Unit 3	Conway, SC 29526	843-516-3601 03/31/16
126213017	Zambito, Sean	Carolina Cool	1294 Surfside Industrial Park	Surfside Beach, SC 29575	843-238-5805 06/30/17

Total: 75

Jasper

Cert No.	Name	Employer	Address	Phone	Expires
127099718	Cribbs, Loy E	Plumb Rite Plumbing Company	395 Shady Oak Cir	Hardeeville, SC 29927	843-784-5285 03/31/18
127130318	Stanley, Scott L	Scott Stanley Plumbing	Po Box 633	Hardeeville, SC 29927	843-597-1857 03/31/18

Total: 2

Kershaw

Cert No.	Name	Employer	Address	Phone	Expires
128205618	Ammons, Thomas L	Crawford Sprinkler Company	Po Box 1267	Lugoff, SC 29078	843-238-9033 12/31/18
128188717	Caulder, David	Caulder Plumbing Company	829 Mill St	Camden, SC 29020	803-424-1098 06/30/17
128126417	Caulder, Robert J	Caulder Plumbing Company	829 Mill St	Camden, SC 29020	803-424-1098 06/30/17
128167317	Chapman, Albert L	Chapman Plumbing	550 Railgate Loop	Lugoff, SC 29078	803-572-5259 12/31/17
128224417	Davis, Robert A	Aspire Fire Sprinkler Inc	Po Box 1310	Elgin, SC 29045	803-427-5858 06/30/17
128266318	Gladden, Thomas C	Agape Services Inc	1745-B Blaney Rd	Elgin, SC 29045	803-788-7632 12/31/18
128099818	Gullard, Norman M	Aspire Fire Protection	57 Hunting Inc	Camden, SC 29020	803-427-5478 06/30/18
128257018	Hall, Ernest D JR	Sacon Plumbing Division	893 White Pond Rd	Elgin, SC 29045	803-438-7320 06/30/18

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 21 of 38

Cert No.	Name	Employer	Address	Phone	Expires
128199917	Harrelson, Charles E	Crawford Sprinkler Company	Po Box 1267	Lugoff, SC 29078	803-438-2994 12/31/17
128203018	Kambeitz, Philip M	Camden Plumbing	102 Price St	Camden, SC 29020	803-427-7753 09/30/18
128793917	Mcleod, Phillip B	Reds Backflow	1441 Dowey Cir	Lugoff, SC 29078	803-432-0009 06/30/17
128238216	Neal, Dustin P	Neal Backflow Service	1124 Mathis Ct	Camden, SC 29020	803-243-8272 06/30/16
128225617	Nealy, Candace V	J B Nealy Lawn Care & Irrigation	2012 Juniper Rd	Lugoff, SC 29078	803-629-2875 06/30/17
128016418	Peake, Furman G	Furman Peake Backflow	1018 Tookiedoo Ln	Elgin, SC 29045	803-960-1379 03/31/18
128220918	Perry, William	Eddie Perrys Landscaping	319 Westridge Rd	Elgin, SC 29045	803-513-0557 03/31/18
128267017	Ray, James	Reds Backflow	1441 Dowey Cir	Lugoff, SC 29078	803-572-1500 06/30/17
128043918	Smith, Sean M	Sean Smith Plumbing	Po Box 161	Elgin, SC 29045	803-466-8903 06/30/18
128211116	Threatt, Daniel L	Threatt'S Backflow Testing & Repair	33 Colony Dr	Camden, SC 29020	803-669-1801 03/31/16
128270417	Truesdale, Robert L	Reds Backflow	1035 Medfield Rd	Lugoff, SC 29078	803-427-0782 06/30/17
128017418	Wannamaker, Thomas R	Crawford Sprinkler Company	Po Box 1267	Lugoff, SC 29078	803-438-2994 06/30/18
128172616	Williams, Roy E	Sunbelt Fire Protection	1003 Berry Ln	Camden, SC 29020	803-420-9208 06/30/16
128021116	Williamson, Timothy W	Crawford Sprinkler Of Sc	Po Box 1267	Lugoff, SC 29078	803-438-2994 03/31/16

Total: 22

Lancaster

Cert No.	Name	Employer	Address	Phone	Expires
129231518	Carnes, Chris	Jerrys Plumbing & Heating	Po Box 2034	Lancaster, SC 29721	803-283-3632 06/30/18
129242616	Carnes, Dustin W	Jerrys Plumbing & Heating	1769 Springdale Rd	Lancaster, SC 29720	803-283-3632 12/31/16
129141417	Carter, Chris B	Carter Quality Plumbing	Po Box 1391	Lancaster, SC 29721	803-285-3678 03/31/17
129037117	Catoe, Marvin D	Catoe Heating & Cooling	7084 Pageland Hwy	Lancaster, SC 29720	803-285-2883 09/30/17
129177516	Cooper, R D	Coopers Plumbing	2591 Robert H Kirk Rd	Lancaster, SC 29720	803-283-0991 09/30/16
129237319	Godbee, Kevin B	Carter Quality Plumbing	1408 Rock Hill Hwy	Lancaster, SC 29720	803-577-6201 03/31/19
129214016	Rabon, Gregory A		1534 Roy Carnes Rd	Lancaster, SC 29720	803-804-7600 06/30/16
129712216	Sanders, Jason M	Eagle Fire Inc	838 Old Camden Monroe Hw	Lancaster, SC 29720	704-301-8272 09/30/16
129175316	Steen, Timothy L	Howards Plumbing & Repair	3305 University Dr	Lancaster, SC 29720	803-286-4790 03/31/16
129155617	Stover, Lanny R	Stover Electrical Service	6386 Beecher Horton Rd	Heath Springs, SC 29058	803-804-4138 06/30/17
129155717	Wilkie, Winston H	Backflow Basics Llc	4017 Hickory View Dr	Indian Land, SC 29707	803-729-8183 12/31/17

Total: 11

Laurens

Cert No.	Name	Employer	Address	Phone	Expires
130024418	Anderson, John T	J T Anderson	Po Box 37	Clinton, SC 29325	864-923-0023 06/30/18
130079416	Doolittle, Freeman J	The Plumber	1502 Whelon Rd	Laurens, SC 29360	864-682-2478 12/31/16

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 22 of 38

Cert No.	Name	Employer	Address	Phone	Expires
130239316	Graham, Steven	Dipple Plumbing Inc	512 W Circle Rd	864-419-8948	09/30/16
130128816	Hammer, Michael J	Century Fire Protection	16012 Hwy 221 S	864-377-0903	03/31/16
130035216	Hogan, Kenneth W	Kens Backflow Testing	54 Poulson Pl	803-646-2651	09/30/16
130111817	Warner, Rick A	Warner Mechanical	Po Box 36	864-923-5273	06/30/17
130157318	Yonce, Chucodie	Speciality Fire Protection	284 Hard Rock Dr	864-809-5035	03/31/18

Total: 7

Lexington

Cert No.	Name	Employer	Address	Phone	Expires
132107517	Anderson, Sundiata A	Plumb Time Plumbing & Drain Servi	121 Carlsbad Ct	803-359-0312	09/30/17
132119418	Anderson, Thomas C	Native Plants Garden Center	2421 Dutch Fork Rd	803-271-2355	06/30/18
132034418	Armstead, Christopher L	Palmetto Automatic Sprinkler Co Inc	Po Box 2927	803-794-1602	09/30/18
132132418	Belz, Michael D	Budget Services	117 Shantel Ct	803-957-3194	06/30/18
132148117	Berrian, John M JR	Carolina Backflow Specialties	217 Morgan Dr	803-359-3355	06/30/17
132083916	Berrian, John M	Carolina Backflow Specialties	217 Morgan Dr	803-359-3355	12/31/16
132262718	Boyleston, Jonathan A	Mr Rooter	Po Box 407	803-356-6813	12/31/18
132242816	Bradley, Jason M	Meetze Plumbing	Po Box 1577	803-732-3747	12/31/16
132247117	Burns, Anthony	AAA Accurate Backflow Testing & R	124 Woodcraft Dr	803-798-1921	06/30/17
132119318	Cannon, Loy E	Cannon Plumbing Inc	212 Lester Frick Rd	803-600-4185	09/30/18
132148217	Chandler, Walter O	Chandler Consulting	105 Cottontail Ln	803-603-2819	06/30/17
132242716	Conner, James M	Meetze Plumbing	Po Box 1577	803-732-3747	12/31/16
132099516	Corcoran, William IV	Complete Plumbing Services Inc	209 Swartz Rd	803-951-9300	09/30/16
132122816	Cottrell, Jason C	Cottrell & Company	831 Whitney Ln	803-256-9570	03/31/16
132241816	Creppon, Bobby	Palmetto Automatic Sprinkler Comp:	1862 Old Dunbar Rd	803-794-1602	09/30/16
132256218	Cunningham, Thomas E	Palmetto Automatic Sprinkler Comp:	Po Box 2927	803-794-1602	06/30/18
132173617	Davis, Daniel J	Gene Love Plumbing	123 Cornish Way	803-348-2452	03/31/17
132121918	Davis, Paul R	Pye Barker Fire & Safety	201 Big Hickory Ln	843-513-0215	12/31/18
132256618	Derrick, Bryan J	Plumbing Solutions Llc	Po Box 973	803-513-5749	06/30/18
132193317	Doby, Henry H JR	Doby'S Plumbing & Gas Company	488 Frye Branch Rd	803-318-2743	06/30/17
132187617	Dowd, Howard	Dowd'S Plumbing	3363 Caulks Ferry Rd	803-397-1854	09/30/17
132271519	Edmonds, Stanley N	Meetze Plumbing Company Inc	Po Box 1577	803-732-3747	03/31/19
132199718	Elswick, William A	Billys Backflows	190 Stonewood Dr	803-309-9477	06/30/18
132035516	Epperson, Richard E		118 Emanuel Dr	803-600-7986	06/30/16
132073416	Estes, Timothy R	Pinnacle Landscape & Design Llc	80 Crossfox Ct	803-513-7981	03/31/16
132195517	Etheredge, Dargan K	Dargans Plumbing	2935 Old State Rd	803-238-2122	12/31/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16

Page 23 of 38

Cert No.	Name	Employer	Address	Phone	Expires
132041217	Gamble, Anthony M	Fast Response Plumbing Llc	Po Box 3451	803-359-0023	03/31/17
132288118	Gandy, R M	K L M Home Solutions Llc	Po Box 1135	803-932-9835	06/30/18
132228918	Garner, John	Frog Level Plumbing Llc	179 Walkbridge Way	803-537-6115	06/30/18
132260118	Harmon, Michael J	Lifeguard Fire Protection Inc	2725 Priceville Rd	803-892-2136	09/30/18
132167817	Hathcox, Jacob D	Carolina Backflow Specialties	217 Morgan Dr	803-359-3355	09/30/17
132211816	Hewitt, Joseph D	Meetze Plumbing	Po Box 1577	803-732-3747	06/30/16
132264019	Hindman, Eric J	Immacu-Wet Ltd Company	648 Tailwater Bend	803-996-3400	03/31/19
132071718	Howard, Ronald W	Howard Irrigation	3220 Glendale Rd	803-739-7153	09/30/18
132211718	Howell, Christopher D	Plumb Crazy Plumbing Service	Po Box 407	803-356-6813	12/31/18
132262218	Howell, Walter J	A A A Accurate Backflow Testing & R	124 Woodcraft Dr	803-798-1921	12/31/18
132173517	Huckabee, Daniel A	Huckabee Plumbing & Gas	324 Watertank Rd	803-513-7728	03/31/17
132237616	Jackson, Michael E	M & M Backflow Testing	820 Fortspond Trail	803-371-7321	03/31/16
132164818	Jeffcoat, James	Carolina Plumbing Of Sc Inc	Po Box 84696	803-957-5005	06/30/18
132231218	Johnson, Willie K	Fast Response Plumbing	Po Box 3451	803-359-0023	12/31/18
132062217	Knight, Kenneth J	Knight'S Plumbing	104 Lloydwood Dr	803-796-8877	09/30/17
132132916	Leroy, James E	Utility Lab Services	127 Ridge Pointe Dr	803-608-4948	12/31/16
132250617	Long, Richard M	Precision Plumbing	1137 Old Swamp Rd	803-791-5820	12/31/17
132247217	Lucas, Johnny R	Cottrell & Company	109 Brentwood Dr	803-237-1995	06/30/17
132256818	Lybrand, James G	Lifeguard Fire Protection Inc	2725 Priceville Rd	803-892-2136	06/30/18
132135716	Mack, Patrick W	Lad Corporation	Po Box 2634	803-739-4483	09/30/16
132256518	Mccumbers, Wendell J	Meetze Plumbing Company	Po Box 1577	803-732-3747	06/30/18
132012416	Miller, Joe M	A A A Accurate Plumbing Heating & A	124 Elvington Ln	803-798-1921	06/30/16
132066918	Mumblow, Anthony G	Fat'S Plumbing & Gas	1410 Parkdale Dr	803-957-1505	03/31/18
132161318	Munsell, Robert J	Palmetto Automatic Sprinkler Comp:	Po Box 2927	803-794-1602	09/30/18
132242516	Nimmo, Tristin C	National Fire & Safety	105 Iron Horse Rd	803-931-2166	12/31/16
132224617	Phillips, John C	Lifeguard Fire Protection Inc	2725 Priceville Rd	803-892-2136	12/31/17
132241416	Pressley, Jeff	Palmetto Automatic Sprinkler Comp:	1862 Old Dunbar Rd	803-794-1602	09/30/16
132180416	Price, Von R	Lifeguard Fire Protection Inc	2725 Priceville Rd	803-892-2136	09/30/16
132007617	Redmond, Rusty H JR	Carolina Backflow Specialties	217 Morgan Dr	803-359-3355	12/31/17
132797517	Richardson, Michael T	Carolina Tap & Bore	2410 Morningside Dr	803-739-7056	09/30/17
132250817	Rodabaugh, Timothy E	1st Choice Plumbing & Gas	117 St Pauls Pl Dr	803-892-3443	12/31/17
132235016	Rogers, Brian	Saluda Hill Inc	2025 Industrial Blvd	803-957-7335	03/31/16
132111018	Sandifer, Steve L	Steves Nursery	316 Ridgecreek Dr	803-600-7747	12/31/18
132249017	Sims, Chad	Palmetto Automatic Sprinkler Comp:	1862 Old Dunbar Rd	803-794-1602	09/30/17
132088117	Smith, Eddie A	The Lawn Smith	116 Colony Lakes Ct	803-359-1229	12/31/17
132253618	Spicer, Johnny L	Spicer On-Call Services	Po Box 390	803-665-0505	03/31/18

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 24 of 38

Cert No.	Name	Employer	Address	Phone	Expires
132256118	Stallings, Timothy J	Plumbing Solutions Llc	Po Box 973	Lexington, SC 29071	803-513-5749 06/30/18
132021916	Steele, John D	John Steele Backflow Service	124 Dutch Dr	Leesville, SC 29070	803-622-4525 03/31/16
132221917	Sturkie, Ernest W	Sturkie Plumbing	138 Joyful Ct	Gaston, SC 29053	803-755-2009 06/30/17
132259618	Taylor, Robert E	Palmetto Automatic Sprinkler Co Inc	Po Box 2927	West Columbia, SC 29171	803-794-1602 09/30/18
132164018	Tefft, Thomas E	Carolina Leak Detection	1840-A Two Notch Rd	Lexington, SC 29073	803-476-5542 12/31/18
132795818	Tefft, Veronica	Carolina Leak Detection	308 Richmond Farm Cr	Lexington, SC 29072	803-785-2376 06/30/18
132123216	Thomas, Frankie L JR	F R C Construction Llc	107 Wagon Wheel Ct	Pelion, SC 29123	803-894-4158 09/30/16
132252618	Tracy, Becky L	Forty Dollar Backflow	1267 S Lake Dr	Lexington, SC 29073	803-463-1559 06/30/18
132223719	Vanbuskirk, Nathan R	Native Plants	2421 Dutchfork Rd	Chapin, SC 29036	803-732-1782 03/31/19
132052618	Venne, Roger C	Mr Rooter	Po Box 407	Lexington, SC 29071	803-356-6813 12/31/18
132272519	Weatherford, Dale	Water Systems Inc	Po Box 3905	West Columbia, SC 29171	803-755-0090 03/31/19
132265817	West, Donna P	Backflow Testing Services	197 Pineview Rd	West Columbia, SC 29169	803-767-6797 09/30/17
132180317	West, Stuart A	Stuart A West	197 Pineview Rd	West Columbia, SC 29169	803-413-2848 12/31/17
132260318	Wilkerson, Jeffrey L	A L R Contracting Inc	100 Blue Pine Ln	Lexington, SC 29073	803-622-9747 09/30/18
132229118	Wooten, Marty W	Annual Backflow Check	970 Skyview Dr	West Columbia, SC 29170	803-206-0057 06/30/18
132186817	Young, Joshua J	Carolina Tap And Bore	2430 Morningside Dr	West Columbia, SC 29169	803-309-5793 09/30/17
132260018	Zimmerman, Brandon	A A A Accurate Backflow Testing	124 Woodcraft Dr	Lexington, SC 29073	803-798-1921 09/30/18

Total: 79

Marion

Cert No.	Name	Employer	Address	Phone	Expires
133268516	Bass, Jimmy G	Jimmy'S Backflow Service	2442 Methodist Church RoacdMarion, SC 29571	843-430-7678	03/31/16
133190117	Beeson, Richard J		3534 North Hwy 41	Mullins, SC 29574	843-464-0611 06/30/17
133151617	Hardwick, Christopher G	C M Backflow Service	6606 South Hwy 41	Marion, SC 29571	843-430-5131 09/30/17

Total: 3

McCormick

Cert No.	Name	Employer	Address	Phone	Expires
135187918	Bowick, Leslie D	Bowicks Repair	940 Red Row Rd	Mccormick, SC 29835	864-378-4600 09/30/18
135793217	Deason, John H	Bee Rite Backflow	1141 Jefferson St	Mccormick, SC 29835	864-443-2661 03/31/17
135126016	Faust, Charles H	Faust Testing	623 Heritage Cove	Mccormick, SC 29835	864-391-5344 09/30/16
135074416	Furqueron, Ben R	Benjamin R Furqueron	325 Christian Rd	Mccormick, SC 29835	864-379-1331 06/30/16

Total: 4

Newberry

Cert No.	Name	Employer	Address	Phone	Expires
136272419	Benepe, Don	Dubose Home Repairs & Plumbing	1122 Jake Eargle Rd	803-586-4107	03/31/19
136272119	Chocklett, Jay B	Chocklett Environmental	Po Box 131	803-940-0508	03/31/19
136010216	Hall, John M	Lide Plumbing	1496 Whitener Rd	803-276-3654	09/30/16
136165816	Hazel, Kevin S	Hazel Plumbing Company Inc	Po Box 812	803-276-6984	12/31/16

Total: 4

Oconee

Cert No.	Name	Employer	Address	Phone	Expires
137185817	Bernshausen, Adam G	Outdoor Escapes Inc	257 Kelly Mill Rd	864-684-4077	03/31/17
137243516	Branson, Patrick L	Hunts Technical Services Inc	186 Hunt Rd	864-972-9816	12/31/16
137013418	Broach, Randy	Keowee Backflow Services	1610 Cross Creek Dr	864-873-4662	03/31/18
137266818	Buzhardt, James M	Certified Backflow Specialist	441 Dynamite Rd	864-944-2830	06/30/18
137260918	Capps, Brandon M	Hunts Technical Services Inc	186 Hunt Rd	864-710-6012	09/30/18
137084717	Cothran, John E	Rainmaker Pond & Irrigation	10227 Clemson Blvd	864-882-0363	03/31/17
137029118	Crooks, David L	Crooks Plumbing & Electrical Inc	120 N Retreat Rd	864-647-9538	03/31/18
137238916	Dodgens, Rickey G	Hunts Technical Service	208 Miller Farm Rd	864-247-2230	06/30/16
137216316	Ellison, Chuck W	Rainmaker Ponds & Irrigation Inc	10227 Clemson Blvd	864-882-0363	12/31/16
137225117	Fisher, James E	Outdoor Escapes Inc	257 Kelly Mill Rd	864-710-8627	03/31/17
137207318	Gravley, Dustin T	Genes Backflow Service	220 Ramsey Creek Rd	864-903-9587	12/31/18
137176218	Gravley, William E	Genes Backflow Service	220 Ramsey Creek Rd	864-903-4579	12/31/18
137002417	Hunt, Steve C	Hunt'S Technical Services	186 Hunt Rd	864-710-6012	12/31/17
137192017	Hunt, William F	Hunt'S Technical Services Inc	186 Hunt Rd	864-557-7763	12/31/17
137243916	Hunt, William L	Hunts Technical Services Inc	186 Hunt Rd	864-972-9816	12/31/16
137267216	Jones, Rick A	Blue Ridge Backflow	499 Frog Valley Rd	864-944-2819	12/31/16
137238816	Kinnard, Trevor T	Zone 7 Nursery	410 Sheep Farm Rd	864-882-7771	06/30/16
137261618	Knight, Daniel J	Rainmaker Inc	10227 Clemson Blvd	864-882-0363	09/30/18
137167718	Melton, David E	Meltons Backflow	112 King James Rd	864-844-3453	06/30/18
137163018	Okelley, Johnny R	Davis Electrical & Plumbing Inc	538 Poplar Springs Rd	864-638-0202	06/30/18
137207518	Parris, Jeffrey S	Genes Backflow Service	220 Ramsey Creek Rd	864-903-2227	12/31/18
137214316	Patterson, Casey L	Zone 7 Nursery	410 Sheep Farm Rd	864-882-7771	06/30/16
137247717	Raines, Dustin	Greenstone Construction Llc	210 W N 2nd St	864-882-5734	09/30/17
137286616	Roach, Chris M	Chris Roach	125 Brook Ln	864-784-4344	09/30/16
137163217	Roach, Zack A	Zack Roach	364 Bountyland Rd	864-723-4910	09/30/17
137202118	Rogers, Lee F	Front Gate Landscapes Llc	202 Brookside Dr	864-723-4171	06/30/18
137224917	Swafford, Michael B	Crooks Plumbing & Electrical Inc	120 N Retreat Rd	864-647-9538	12/31/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 26 of 38

Cert No.	Name	Employer	Address	Phone	Expires
137102216	Vaughn, Brian	One Flush Plumbing Inc	Po Box 1297	864-903-5452	12/31/16
137123618	Wald, Charles E	Davis Electrical & Plumbing Inc	538 Poplar Springs Rd	864-638-0202	06/30/18
137250417	Wood, Roy A	Backflow Specialties & Plumbing	909 Sanders Cove	443-340-2167	12/31/17
137124017	Ziegler, Robert J	Neighborhood Plumbing	Po Box 1643	864-710-6794	03/31/17

Total: 31

Orangeburg

Cert No.	Name	Employer	Address	Phone	Expires
138059416	Balthaser, Irvin S	Aspire Fire Sprinkler Inc	Po Box 268	803-427-5627	06/30/16
138046618	Bennett, Eugene E JR	Bennett Plumbing	260 Bridge St	803-274-8988	03/31/18
138242416	Clayton, Adam H	Thompson Construction	Po Box 503	803-539-5503	12/31/16
138223318	Jeffcoat, Alvin	Jeffcoat Water Services	6567 Farrelles Rd	803-245-4262	09/30/18
138261818	Shuler, Stephen W	Pooser Plumbing	269 Fountain Lake Dr	803-492-7193	09/30/18
138236016	Sikes, Marion D III	Callahan Backflow	1695 Murph Mill Rd	803-308-3299	03/31/16
138110218	Sox, Donald M	Midlands Fire Protection	316 Kaigler Rd	803-518-1117	03/31/18
138019516	Wise, Willie B	G B S Home Repair Service	500 Hayden Rd	803-361-4882	03/31/16
138186416	Zorn, David W JR	Zorn Consulting Llc	325 Banning St	803-536-6387	09/30/16

Total: 9

Pickens

Cert No.	Name	Employer	Address	Phone	Expires
139239016	Abercrombie, Jeffrey D	D J'S Equipment & Services	509 Martin School Rd	864-506-5736	06/30/16
139096316	Blackwell, Hugh V III	H V Blackwell Plumbing Inc	161 Clear Creek Rd	864-430-5923	09/30/16
139232218	Brewer, Arthur T	Easley Mechanical Services Inc	111 Neal St	864-859-4976	12/31/18
139272617	Camp, Roger D	Westminster Company	201 West Ln	864-643-6343	03/31/17
139264416	Clark, Josh E	A Yard Of Dreams Inc	2619 Saluda Dam Rd	864-354-4580	12/31/16
139039018	Costello, Donnie D	Backflow Prevention & Testing	237 S Glassy Mountain Rd	864-878-0695	12/31/18
139095616	Culbreth, Charles E	J C Plumbing Llc	220 Fuller Dr	864-269-5360	09/30/16
139121517	Deck, Tim G	General Backflow Testing	205 Holly Dr	864-859-6106	06/30/17
139162918	Goss, Robby J	Beckwith Plumbing	101 Goldman St	864-654-4119	06/30/18
139792516	Jenkins, Kenneth S	A Plus Backflow Testing	136 Red Hawk Rd	864-350-8534	12/31/16
139120916	Laney, James E	J J'S Landscaping & Lawn Maintena	Po Box 1102	864-637-9199	06/30/16
139207816	Leopard, Ernest D	Leopards Irrigation	224 Carson Rd	864-350-0538	12/31/16
139189617	Lesley, Lonnie J	Fire Fighter Backflow Testing	354 Adger Rd	864-430-7884	06/30/17
139187117	Lewis, Dee	Lewis Systems	240 Earle Dr	864-915-6333	09/30/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 27 of 38

Cert No.	Name	Employer	Address	Phone	Expires
139244917	Page, Travis R	Provident Plumbing	104 Nancy Dr	Easley, SC 29642	864-430-4416 03/31/17
139245717	Schmidt, Frank A	Frank'S Plumbing	200 Mcbee Ave	Easley, SC 29640	864-449-8508 03/31/17
139129916	Smith, Kenneth L JR		226 Spur Rd	Six Mile, SC 29682	864-506-4081 03/31/16
139140117	Weaver, Patrick A	Patrick Weaver	305 Monaco Cir	Clemson, SC 29631	864-986-1079 03/31/17

Total: 18

Richland

Cert No.	Name	Employer	Address	Phone	Expires
140051316	Banks, John R	Banks Backflow Services	Po Box 25003	Columbia, SC 29224	803-807-1019 12/31/16
140097917	Banks, John W	Banks Backflow Services	Po Box 25003	Columbia, SC 29224	803-463-0059 06/30/17
140155918	Bradshaw, Brian	Franklin Plumbing Company	1804 Shop Rd	Columbia, SC 29201	803-979-6025 03/31/18
140177216	Brandon, Dwayne A	Capital City Plumbing	Po Box 155	Columbia, SC 29203	803-794-2474 03/31/16
140155017	Braun, Nicholas K	W O Blackstone	Po Box 88	Columbia, SC 29202-0088	803-252-8222 12/31/17
140108718	Brazell, Kenny W	T Edward Cooper Company Inc	613 Blythewood Rd	Blythewood, SC 29016	803-754-2805 03/31/18
140262418	Bullock, Jacob K	Heads Up Irrigation	9 Tip Top Ct	Irmo, SC 29063	803-360-1260 12/31/18
140100818	Butler, Brian M	B MB Landscape & Lighting Inc	Po Box 582	Blythewood, SC 29016	803-714-5566 03/31/18
140132417	Campbell, Tony R	Northeast Backflow	1138 Otis Richardson Rd	Lugoff, SC 29078	803-309-0841 03/31/17
140180816	Carr, Daniel C	National Fire & Safety	701 Gervais St Ste 150-192	Columbia, SC 29201	843-476-3833 09/30/16
140203719	Chavis, Joseph E	Joseph E Chavis Plumbing	329 Devonport Dr	Irmo, SC 29063	803-237-9973 03/31/19
140237916	Chavis, Nicholas S	Heads-Up Irrigation Sc Llc	9 Tip Top Ct	Irmo, SC 29063	803-360-1260 06/30/16
140023218	Cipriano, Charles W JR	O'Neal Plumbing & Backflow Specia	Po Box 90811	Columbia, SC 29290	803-776-5514 06/30/18
140250117	Cipriano, Preston M	Oneal Plumbing & Backflow Special	Po Box 90811	Columbia, SC 29290	803-776-5514 12/31/17
140093816	Clarkson, Chip C	Palmetto Green Landscaping Inc	Po Box 182	Hopkins, SC 29061	803-695-0180 06/30/16
140251717	Coleman, Clyde J		1577 Congaree Rd	Hopkins, SC 29061	803-640-6357 12/31/17
140245817	Coppage, David K	Naturescapes Landscaping & U S L	1313 Carnes St	Columbia, SC 29204	803-549-9086 03/31/17
140262518	Cranford, James	National Fire & Safety	701 Gervais St Ste 150-192	Columbia, SC 29201	843-476-3833 12/31/18
140052816	D'Anna, Patrick J	Castle Automatic Sprinkler Co.	3 Dunes Point	Blythewood, SC 29016	803-419-2121 06/30/16
140199117	Davies, Chris	Heads Up Irrigation Sc Llc	9 Tip Top Ct	Irmo, SC 29063	803-360-1260 12/31/17
140218516	Dawkins, Christopher G	Shady Grove Construction	Po Box 754	White Rock, SC 29177	803-781-2516 12/31/16
140262018	Dillard, Edward	Heads Up Irrigation	9 Tip Top Ct	Irmo, SC 29063	803-360-1260 12/31/18
140247417	Dimig, Patrick	Hay Hill Services	1625 Bluff Rd	Columbia, SC 29201	803-834-6652 06/30/17
140387218	Dixon, Matthew A	Dixons Plumbing Service	2913 Rawlinson Rd	Columbia, SC 29209	803-556-9588 06/30/18
140068117	Donaldson, Thomas MJF	A & T Plumbing Inc	218 Glenridge Ct	Columbia, SC 29212	803-600-5928 06/30/17
140249117	Fabbro, John W	Apple Services	Po Box 3965	Irmo, SC 29063	803-749-1751 09/30/17
140795717	Goodlet, Joshua M	J G'S Backflow Testing	1929 Horrell Hill Rd	Hopkins, SC 29061	803-402-2045 09/30/17

Cert No.	Name	Employer	Address		Phone	Expires
140193717	Graham, James T	Walker White	5728 Shakespeare Rd	Columbia, SC 29223	803-691-0918	12/31/17
140203118	Hagins, Archie L	Meetze Plumbing Company	10009 Broad River Rd	Irmo, SC 29063	803-732-3747	06/30/18
140109418	Hamby, Matthew T	Apple Services	Po Box 3965	Irmo, SC 29063	803-749-1751	03/31/18
140250217	Hester, Ricky	Walker White Inc	5728 Shakespeare Rd	Columbia, SC 29223	803-691-0918	12/31/17
140177816	Hobby, Tommie L	Meetze Plumbing Company	10009 Broad River Rd	Irmo, SC 29063	803-732-3747	09/30/16
140262318	Howe, Joshua C	Aero Services	Po Box 23213	Columbia, SC 29224	803-736-9300	12/31/18
140248917	Janson, Eric G	National Fire & Safety	701 Gervais St Ste 150-192	Columbia, SC 29201	803-542-0897	09/30/17
140108417	Jennings, James R	Bob'S Backflow	421 S Main St	Prosperity, SC 29127	803-401-0044	09/30/17
140220517	Jordan, Devan R	Apple Services	Po Box 3965	Irmo, SC 29063	803-749-1751	09/30/17
140291118	Lockey, Charles W	B & C Backflow	133 Rockefella Ln	Columbia, SC 29223	803-315-6030	12/31/18
140246817	Massengill, Maxwell M	Aero Plumbing	Po Box 23213	Columbia, SC 29224	803-736-9300	06/30/17
140020116	Medlin, Michael H JR	Mikes Water Service	2820 Hobkirk Rd	Columbia, SC 29223	803-788-5211	06/30/16
140034018	Medlin, Michael H	Mike'S Water Service	2820 Hobkirk Rd	Columbia, SC 29223	803-788-1170	06/30/18
140248617	Miller, Jeannene M	Cuz Plumbing Llc	1100 Lykes Ln	Irmo, SC 29063	803-749-3457	09/30/17
140248517	Miller, Rodney	Cuz Plumbing Llc	1100 Lykes Ln	Irmo, SC 29063	803-553-9687	09/30/17
140259718	Moore, Rodney C	Franklin Plumbing & Drain Cleaning	Po Box 90833	Columbia, SC 29290	803-799-2222	09/30/18
140208918	Orzechowski, Konrad M	Kay Plumbing Services Llc	6030 St Andrews Rd Ste H	Columbia, SC 29212	803-445-3707	09/30/18
140272019	Pender, Joseph D	Yelton Plumbing	208 Rocky Point Dr	Columbia, SC 29212	803-397-0700	03/31/19
140052318	Pittman, Marcus G	Southern Atlantic Mechanical Comp	3770 Fernandina Rd	Columbia, SC 29210	803-260-4653	03/31/18
140056019	Potts, Charles E	Potts Plumbing Company	5400 Bluff Rd	Columbia, SC 29209	803-776-5164	03/31/19
140205416	Rabon, Jason M	W B Guimarin	1001 True St Apt 403	Columbia, SC 29209	803-586-8838	09/30/16
140170518	Reed, Ken W	A-1 Backflow	20 School Yard Ct	Columbia, SC 29209	803-360-6917	06/30/18
140266716	Riley, Roger	Riley & Son Backflow Testers	7538 Stone St	Columbia, SC 29209	803-783-0425	06/30/16
140713316	Scott, Ernest H	All American Backflow	3890 Mccords Ferry Rd	Eastover, SC 29044	803-464-1072	09/30/16
140156418	Threadgill, Fred D	A B V Services	2901 Screaming Eagle Rd	Lugoff, SC 29078	803-788-3473	03/31/18
140017718	Threadgill, Ray	Advanced Rays Enterprise	2427 Alpine Rd	Columbia, SC 29223	803-422-5449	03/31/18
140075218	Tidwell, Sherwood F	Sherwoods Plumbing Service	1776 Morninglo Ln	Columbia, SC 29223	803-479-1391	06/30/18
140238016	Trimnal, Scotty	Franklin D Plumbing Services	Po Box 9481	Columbia, SC 29290	803-788-1499	06/30/16
140223118	Wagner, Bret A	G C A Services - Physical Plant	1600 Harden St	Columbia, SC 29204	803-422-1769	03/31/18
140150717	Williams, Billy R	Forty Dollar Backflow	3623 Traveler Ln	Columbia, SC 29209	803-463-1559	06/30/17
140257118	Williams, William B	Sensor Enterprises	3924 Forest Dr Ste 12	Columbia, SC 29204	803-361-8609	06/30/18
140251817	Yeh, Peter W	Peter Yeh Llc	235 E Dean Rd	Irmo, SC 29063	808-404-7394	12/31/17
140200118	Youngblood, Greg	W O Blackstone	Po Box 88	Columbia, SC 29202-0088	803-252-8222	09/30/18

Total: 60

Cert No.	Name	Employer	Address	Phone	Expires
141090316	Bedenbaugh, James C JI	B & B Backflow Testing	3401 Spann Rd	Leesville, SC 29070	803-532-9092 06/30/16
141716716	West, Ricky	West Backflow Services	2889 Prosperity Hwy	Leesville, SC 29070	803-413-3098 12/31/16
Total: 2					

Spartanburg

Cert No.	Name	Employer	Address	Phone	Expires
142213916	Aho, Bryan	Roto Rooter	Po Box 577	Roebuck, SC 29376	864-582-2670 06/30/16
142168818	Babb, Kevin C	Babb'S Plumbing & Backflow Service	164 Bradshoars Rd	Campobello, SC 29322	864-303-6541 03/31/18
142061317	Bagwell, Donald R	Custom Plumbing & Electric	387 Edwards Rd	Inman, SC 29349	864-706-0326 12/31/17
142228618	Ball, James J	Plumbing Matters	4875 Hwy 11	Inman, SC 29349	864-809-2012 03/31/18
142111516	Blankenship, Karl D	Simplex Grinnell	2788 Fairforest Clevedale Rd	Spartanburg, SC 29301	864-641-2110 09/30/16
142157617	Boyer, John R JR	A-1 Affordable Backflow	216 Circle Dr	Woodruff, SC 29388	864-848-1113 06/30/17
142263118	Brock, Timothy R	I S S	347 Double Bridge Rd	Boiling Springs, SC 29316	864-505-6745 12/31/18
142150916	Burdette, Steve	Simplex Grinnell	2788 Fairforest Clevedale Rd	Spartanburg, SC 29301	864-641-2110 06/30/16
142091518	Burke, Ricky A	C J Compton Plumbing Inc	7606 Prince St	Spartanburg, SC 29303	864-503-0337 12/31/18
142191617	Burrell, Timothy M	Burrell Backflow	Po Box 89	Pacolet Mills, SC 29373	864-585-8296 09/30/17
142047317	Butt, Michael D	Waldrop Mechanical Services	1651 Montgomery Dr	Chesnee, SC 29323	864-612-4030 12/31/17
142272919	Cantrell, Johnny C	Simplex Grinnell	2788 Fairforest Clevedale Rd	Spartanburg, SC 29301	864-641-2110 03/31/19
142218016	Cooper, Kenneth C	Operation Drains Of The Upstate	Po Box 5532	Spartanburg, SC 29304-5532	864-582-8682 12/31/16
142217916	Corey, Alan R	A R C Mechanical Services	123 McDonald Farms Dr	Chesnee, SC 29323	864-703-2721 12/31/16
142270016	Davis, Kenneth A	Professional Backflow Service	281 Prominence Ridge Dr	Chesnee, SC 29323	864-208-6334 06/30/16
142257618	Davis, Michael B	Davis Services Inc	111 Davis Rd	Spartanburg, SC 29303	864-578-9233 06/30/18
142153317	Deloach, Harry O	T S A Inc	201 Carolina Club Dr	Spartanburg, SC 29306	864-583-0704 12/31/17
142135418	Edwards, James A	Upstate Backflow Testers	112 Glyn Oaks Dr	Boiling Springs, SC 29316	864-494-1297 09/30/18
142251217	Emert, Gregory H	Southcorp Properties	105 Turning Leaf Cir	Boiling Springs, SC 29316	864-809-1682 12/31/17
142257718	Evans, Charles E	Roto Rooter	2149 E Blackstock Rd	Roebuck, SC 29376	864-595-0188 06/30/18
142191817	Galloway, William L	Excel Fire Sprinkler Company	Po Box 332	Roebuck, SC 29376	864-451-3206 09/30/17
142178316	Garrett, Michael S	W N Kirkland	2409 S Pine St	Spartanburg, SC 29302-4333	864-582-6701 09/30/16
142791417	Gosnell, Allen W		200 Glassy Rd	Landrum, SC 29356	864-505-3987 06/30/17
142258118	Harris, Elijah	Davis Services Inc	111 Davis Rd	Spartanburg, SC 29303	864-578-9233 06/30/18
142218116	Horton, William G	Operation Drains Of The Upstate	Po Box 5532	Spartanburg, SC 29304-5532	864-582-8682 12/31/16
142174816	Hyder, Austin B	Hyder Plumbing Company Inc	615 N Howard Ave	Landrum, SC 29356-1118	864-457-4568 03/31/16
142183317	Jackson, Christopher L	Creative Lawns	303 Slate Dr	Boiling Springs, SC 29316	864-444-5626 03/31/17
142030016	Jolly, Dennis W	Jollys Septic & Sewer Service	148 Laurens St	Cowpens, SC 29330	864-641-9529 12/31/16
142258218	King, Tore S	Roto Rooter	2149 E Blackstock Rd	Roebuck, SC 29376	864-595-0188 06/30/18

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 30 of 38

Cert No.	Name	Employer	Address	Phone	Expires
142217816	Lucas, Bruce E	Simplex Grinnell	2788 Fairforest Clevedale RcSpartanburg, SC 29301	864-327-6580	12/31/16
142142716	Martin, Jesse P	American General Plumbing	210 Spring Wood Dr Spartanburg, SC 29302	864-285-1456	12/31/16
142168418	McCall, James C	Pye Barker Fire & Safety	Po Box 477 Drayton, SC 29333	864-504-0106	12/31/18
142285017	Mills, Bryson D	Mills Plumbing	214 Battleground Rd Cowpens, SC 29330	864-505-0591	09/30/17
142027416	Morgan, Walter L	AD W Inc	334 B Wingo Heights Rd Spartanburg, SC 29303	864-582-4444	06/30/16
142043418	Owens, Roger W	W R Owens Plumbing Inc	119 Watts Ln Pauline, SC 29374	864-304-4543	06/30/18
142213816	Pruner, Jeffrey A	Simplex Grinnell	2788 Fairforest Clevedale RcSpartanburg, SC 29301	864-641-2110	06/30/16
142058318	Rosborough, Chris M	C J Compton Plumbing Company	7606 Prince St Spartanburg, SC 29303	864-503-0337	12/31/18
142271919	Ruchala, Joseph F	W N Kirkland Inc	Po Box 5425 Spartanburg, SC 29304	864-582-6701	03/31/19
142102316	Schults, Ricky D	Interstate Mechanical & Millwright Inc	Po Box 1209 Roebuck, SC 29376	864-583-4286	12/31/16
142018616	Settle, David C	David Settle Landscape Co	550 Old Settle Rd Inman, SC 29349	864-472-3921	09/30/16
142255518	Settle, John P	Jolly's Septic & Sewer Service	148 Laurens St Cowpens, SC 29330	864-641-9529	03/31/18
142179916	Sexton, John D	Pye-Barker Fire & Safety Inc	1765 Drayton Rd Drayton, SC 29333	864-207-6299	12/31/16
142797918	Shands, Boyd	Shands Backflow Testing	143 Ingles Dr Pacolet, SC 29372	864-415-0088	09/30/18
142061116	Shook, Daniel L	Century Company	Po Box 2342 Spartanburg, SC 29304	864-576-0942	09/30/16
142241516	Smith, Allen	W N Kirkland Inc	2409 S Pine St Spartanburg, SC 29302-4333	864-582-6701	09/30/16
142258418	Smith, James	Davis Services Inc	111 Davis Rd Spartanburg, SC 29303	864-578-9233	06/30/18
142202618	Smith, Mark D	C B Smith Plumbing & Associates	Po Box 160455 Boiling Springs, SC 29316	864-574-4275	06/30/18
142066616	Smith, Toney R	A B C Backflow	1607 Green Pond Rd Woodruff, SC 29388	864-266-2341	06/30/16
142166117	Stowe, Floyd C	Simplex Grinnell	2788 Fairforest Clevedale RcSpartanburg, SC 29301	864-574-7373	06/30/17
142247517	Sylvester, Donald A	Roto Rooter	2149 E Blackstock Rd Roebuck, SC 29376	864-595-0188	09/30/17
142196419	Theye, Preston K	One Call Plumbing	457 S Daniel Morgan Ave Spartanburg, SC 29306	864-310-6277	03/31/19
142100218	Tinsley, Mark	Spartan Backflow	Po Box 161174 Boiling Springs, SC 29316	864-814-1646	12/31/18
142119718	Tinsley, Pam J	Spartan Backflow	Po Box 161174 Boiling Springs, SC 29316	864-814-1646	12/31/18
142248317	Walton, James	Simplex Grinnell	2788 Fairforest Clevedale RcSpartanburg, SC 29301	864-641-2110	09/30/17
142232418	Wilson, Chad A	Professional Plumbing Contractors	140 Alverson Rd Campobello, SC 29322	864-809-5365	09/30/18
142251317	Windham, Daniel K	Waldrop Mechanical Services	8345 Taylor Colquitt Rd Spartanburg, SC 29303	864-578-7252	12/31/17
142175816	Wofford, John F JR	Wofford Backflow Testing	561 River Rd Cowpens, SC 29330	864-463-7510	03/31/16
142014318	Wright, Dale A	Dale Wright	131 Crescent Dr Moore, SC 29369	864-590-8142	06/30/18

Total: 58

Sumter

Cert No.	Name	Employer	Address	Phone	Expires
143063016	Barrineau, Jimmie	Lee Construction Company	Po Box 865 Sumter, SC 29151	803-775-8509	03/31/16
143237416	Daugherty, Leigh A	Daugherty & Sons Plumbing Company	1554 Bradham Blvd Sumter, SC 29153	803-464-2976	03/31/16

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 31 of 38

Cert No.	Name	Employer	Address	Phone	Expires
143237516	Daugherty, Sidney M	Daugherty & Sons Plumbing Compai	1554 Bradham Blvd	Sumter, SC 29153	803-236-6694 03/31/16
143234816	Ducom, Rett S	Stanley Drake Construction Compa	366 Neeley St	Sumter, SC 29150	803-506-2584 03/31/16
143226818	Galloway, John R JR	Hill Plumbing	438 N Main St	Sumter, SC 29150	803-773-6689 03/31/18
143257318	Hodge, Timothy D	Smoak Irrigation Company	Po Box 163	Pinewood, SC 29125	803-773-3400 06/30/18
143260618	Houston, Christopher M	Houston Plumbing Company	140 Tiger Lily Rd	Sumter, SC 29153	803-968-9898 09/30/18
143127118	Huber, Jack W	Dependable Roys Plumbing Service	2780 Sing Dr	Sumter, SC 29150	803-469-9171 12/31/18
143013118	Huber, Roy D	Roys Backflow Service	20 W Gloucester Ct	Sumter, SC 29150	803-316-6858 12/31/18
143062916	Lee, Herbert P	Lee Construction Company	Po Box 865	Sumter, SC 29151	803-775-8509 03/31/16
143234916	Linton, Doug	Stanley Drake Construction Compa	366 Neeley St	Sumter, SC 29150	803-506-2584 03/31/16
143128416	Osborne, Jamie L	Osborne Plumbing	2260 Nettles Rd	Sumter, SC 29154	803-840-8982 03/31/16
143193217	Rodgers, David	Barwick Plumbing Company	Po Box 402	Pinewood, SC 29125	803-452-5755 09/30/17
143060518	Rourk, William D	Rourk Plumbing	7 Stelle St	Sumter, SC 29150	803-775-9317 06/30/18
143270516	Tucker, James E	American Backflow Testers	20 Marsden Pl	Sumter, SC 29154	803-499-1199 12/31/16
143388518	Wyen, Joseph	Cabana Boy Cross Connection Con	1835 Canberra Dr	Sumter, SC 29153	803-468-3798 06/30/18

Total: 16

Union

Cert No.	Name	Employer	Address	Phone	Expires
144139117	Boulware, Paul H	Boulware Plumbing & Construction	304 Beltline Rd	Union, SC 29379	864-427-0174 03/31/17
144232618	Cooper, Matthew R	Integrity Backflow	156 Jrm Rec Rd	Enoree, SC 29335	864-804-9059 06/30/18
144178416	Henderson, Brian K	Henderson Plumbing & Mechanical	105 Spruce St	Union, SC 29379	864-427-3779 09/30/16
144215118	Jones, E K	General Planned Maintenance	819 Bob Little Rd	Jonesville, SC 29353	864-426-0728 06/30/18
144032617	Jordan, Louis M JR	Jordans Ace Hardware	489 Buffalo W Springs Hwy	Union, SC 29379	864-427-9077 06/30/17
144149717	Smith, Clint	C B S Backflow Testing	1121 S Jonesville Hwy	Jonesville, SC 29353	864-441-4978 09/30/17
144168118	Tyler, Michael R	General Planned Maintenance	4086 Buffalo W Springs Hwy	Jonesville, SC 29353	864-426-3333 06/30/18

Total: 7

York

Cert No.	Name	Employer	Address	Phone	Expires
146217617	Adams, Barry N	Adams Services Llc	928 E Main St	Rock Hill, SC 29730	704-400-6221 09/30/17
146716818	Berry, Philip A	Adams Services Llc	928 E Main St	Rock Hill, SC 29730	803-242-4379 12/31/18
146234218	Blue, Chris L	Fling Plumbing	Po Box 506	Fort Mill, SC 29716	803-547-5303 12/31/18
146179016	Breakfield, Danny W	All Plumbing Enterprises	240 Victoria Cir	York, SC 29745	803-417-1507 09/30/16
146113318	Brigman, William L	H2o Systems	Po Box 5148	Lake Wylie, SC 29710	803-831-9444 03/31/18
146037517	Buckley, Francis MSR	Powers Construction Company	314 N Congress St	York, SC 29745	803-412-4064 06/30/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 32 of 38

Cert No.	Name	Employer	Address		Phone	Expires
146132616	Carter, Charles T	1st Choice Plumbing	1676 Elderwood Rd	Rock Hill, SC 29732	803-327-5555	09/30/16
146051018	Clinton, Christopher G	G C Backflow Testing	3051 Clinton Dairy Rd	Clover, SC 29710	980-275-9894	03/31/18
146242016	Cloninger, David A	AAA City Plumbing Inc	Po Box 37585	Rock Hill, SC 29732	803-327-5171	12/31/16
146239216	Conrad, Kyle	Edwards Lawn Care Of Sc Inc	1646 West Hwy 160 #8154	Fort Mill, SC 29708	803-548-2640	09/30/16
146717319	Corrigan, Daniel M	A-1 Backflow Testing	829 Gentlewinds Ct	Fort Mill, SC 29708	803-493-6746	03/31/19
146133516	Dover, Scotty	Doan Sun Llc	930 Hwy 321 Bypass	York, SC 29745	803-628-0949	06/30/16
146200217	Edwards, Richard J	Edwards Lawn Care Of Sc Inc	1646 W Hwy 160 #8154	Fort Mill, SC 29708	803-548-2640	12/31/17
146199818	Edwards, Robert E	Edwards Lawn Care Of Sc Inc	1646 West Hwy 160 #8154	Fort Mill, SC 29708	803-548-2640	06/30/18
146002318	Fling, Michael D JR	Fling Irrigation Inc	Po Box 506	Fort Mill, SC 29716	803-547-5303	12/31/18
146064817	Helms, Max G	M G H T 2	2200 Gold Hill Rd	Fort Mill, SC 29708	803-389-3196	03/31/17
146167417	Ingram, Eulys	Adams Services Llc	Po Box 451	Fort Mill, SC 29716	803-547-9796	09/30/17
146139016	Inkelaar, Dean R	AAA City Plumbing Company	Po Box 37585	Rock Hill, SC 29732	803-327-5171	09/30/16
146263718	Jedrzejewski, Victor W	Roto Rooter	3348 Masters Dr	Rock Hill, SC 29732	803-524-0271	12/31/18
146076819	Jones, Bobby L	J & K Irrigation	1996 Shadow Oaks Dr	Rock Hill, SC 29730	803-517-7597	03/31/19
146233118	Jones, Jason D	J & K Irrigation	1996 Shadow Oak Dr	Rock Hill, SC 29730	803-327-9146	12/31/18
146172518	Jordan, Tommie A	AAA City Plumbing	622 Kenwood Ln	Rock Hill, SC 29730	803-322-5427	06/30/18
146127918	Kelly, Danny	Kelly Plumbing	466 S Shiloh Rd	York, SC 29745	803-325-5397	12/31/18
146242116	Kephart, Donald W	Doan Sun Llc	930 Hwy 321 Bypass	York, SC 29745	803-628-0949	12/31/16
146201618	Kruft, Darrin E	Kruft Contracting Inc	1822 Lillian Ln	Fort Mill, SC 29708	704-724-8490	06/30/18
146792816	Lehman, Gary J	Eagle Fire Inc	229 Tributary Dr	Rock Hill, SC 29732	704-497-8683	12/31/16
146132516	Marshall, Bradford S	Bradford'S Backflow	601 Keowee Ln	Fort Mill, SC 29708	803-802-1750	09/30/16
146161418	Mitchell, Donald W	Simplex Grinnell	331 Harper Rd	York, SC 29745	704-241-6025	06/30/18
146040717	Neeley, Dennis P	Fling Plumbing	Po Box 506	Fort Mill, SC 29716	803-242-8589	09/30/17
146240716	Newell, Kenneth D	Simplex Grinnell	1511 Brookbend Ct	Fort Mill, SC 29715	704-501-0521	09/30/16
146256318	Palmer, Thomas J III	AAA City Plumbing Inc	Po Box 37585	Rock Hill, SC 29732	803-327-5171	06/30/18
146046718	Peart, Harry G III	Peart Plumbing Company	214 Twin Lakes Rd	Rock Hill, SC 29732	803-327-0927	03/31/18
146013218	Peart, Harry G JR	Peart Plumbing Company	214 Twin Lakes Rd	Rock Hill, SC 29732	803-417-1014	12/31/18
146009816	Price, John L	John Price	1565 Covenant Pl	Rock Hill, SC 29732	803-487-1218	06/30/16
146037316	Quine, Jon R	Southern Plumbing	1217 Cedar Grove Ln	Rock Hill, SC 29732	803-367-7064	06/30/16
146259818	Smith, Eric	1st Choice Plumbing Llc	1676 Elderwood Rd	Rock Hill, SC 29732	803-417-6730	09/30/18
146209416	Wallace, John H	Professional Lawn Systems Inc	Po Box 4616	Rock Hill, SC 29732	803-327-1415	03/31/16
146253318	Watts, David L	Owens Landscaping Inc	Po Box 369	Bowling Green, SC 29703	803-222-7555	03/31/18
146287218	Wheeler, Brian K	Performance Fire Protection	144 Pheasant Ridge Cir	York, SC 29745	704-507-9195	12/31/18
146176218	Windham, Keith H	Keith Windham Backflows	1450 London Dr	Rock Hill, SC 29732	803-327-3938	06/30/18
146201818	Wright, Benjamin D	Ben Wright Backflow	213 E Old Limestone Rd	York, SC 29745	803-487-2366	06/30/18

Out of State

Cert No.	Name	Employer	Address		Phone	Expires
195184916	Adams, Benjamin T	Fire Technology Llc	2005 Westside Dr	Augusta, GA 30907	706-945-7145	12/31/16
195795217	Alcala, Christopher R	M Z D Plumbing & Backflow Preventi	10501 Meadow Hollow Dr	Mint Hill, NC 28227	704-840-7188	12/31/17
195129818	Anderson, David Y	Unifour Fire & Safety	Po Box 9489	Hickory, NC 28603	828-328-6363	12/31/18
195797318	Armstrong, Michael A	Eagle Fire Inc	570 Griffith Rd	Charlotte, NC 28217	704-339-3579	06/30/18
195241616	Arnold, Jarrett P	International Fire Protection Inc	6935 Oak Ridge Commerce	Austell, GA 30168	770-745-4530	09/30/16
195126518	Arnold, Michael W	Arnolds Plumbing Llc	1020 Bennock Mill Rd	Augusta, GA 30906	706-691-6613	12/31/18
195715517	Bambury, Justin F	Rainmaker Irrigation	10417 Callicut Spring Ct	Huntersville, NC 28078	704-896-6200	12/31/17
195714117	Bange, James W	Fire & Life Safety America	801 Biscayne Dr	Concord, NC 28027	704-326-6644	09/30/17
195213616	Bargeron, James D	Hardy Welding & Piping Services	Po Box 58	Appling, GA 30802	706-541-9192	06/30/16
195184217	Bateman, Virgil J II	Yohe Plumbing Company	Po Box 211282	Martinez, GA 30917	706-854-1889	06/30/17
195269216	Bauguess, Reggie L	Lake Norman Fire Equipment	290 Haymore Dr	Winston Salem, NC 27107	704-652-2913	12/31/16
195171016	Baynard, James L	All Fire Service	220 Lansdale Ave	Lincolnton, NC 28092	704-929-8345	03/31/16
195213317	Bessey, Michael C	V S C Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-805-9700	06/30/17
195716318	Black, Jason K	Sunland Fire Protection	6420-B Windmill Way	Wilmington, NC 28405	910-443-3782	06/30/18
195794917	Blackwell, Jeremy H	Unifour Fire & Safety	Po Box 9489	Hickory, NC 28603	828-328-6363	09/30/17
195111418	Blume, Bradley S	Elite Fire Control Inc	Po Box 1573	Salisbury, NC 28145	704-633-1644	03/31/18
195792216	Boggs, Jimmy D		Po Box 62751	Virginia Beach, VA 23466	757-635-3001	09/30/16
195159318	Boltwood, Christopher J	Wayne Automatic Fire Sprinklers	4370 Motorsports Dr	Concord, NC 28027	704-782-3032	06/30/18
195793717	Brakovec, Bryan J	B B I	Po Box 690273	Charlotte, NC 28227	704-545-1661	03/31/17
195792016	Buchanan, Billy R JR	Fire & Life Safety	1702 4th St	Salisbury, NC 28144	704-886-5733	09/30/16
195715718	Buchanan, Thomas L	T B Backflow	4731 Across Field Ct	Minden, NC 28650	828-228-9587	06/30/18
195795918	Bumgarner, David W	Century Fire Protection	1227 26th Street Se	Hickory, NC 28602	828-328-3802	03/31/18
195110717	Cartee, Michael J	Augusta Backflow	Po Box 935	Augusta, GA 30903	706-799-0337	09/30/17
195732116	Certain, Corey J	Siemens Industries	2201 Crown Point Executive	Charlotte, NC 28227	704-847-1680	03/31/16
195271017	Cliffe, Thomas P	Jim Dickerson Plumbing	7832 Pence Rd	Charlotte, NC 28215	704-331-0544	12/31/17
195794317	Coleman, Kenneth J	Psycho Plumbing	702 Springer Dr	Lawrenceville, GA 30043	770-614-9032	06/30/17
195240816	Collier, Justin A	International Fire Protection Inc	6935 Oak Ridge Commerce	Austell, GA 30168	770-745-4530	09/30/16
195798418	Crabtree, Ormand J	Performance Fire Protection	181 Gasoline Alley	Mooresville, NC 28117	803-417-6374	12/31/18
195183016	Crowe, Chris J	Protection Systems Technologies	Po Box 411821	Charlotte, NC 28241	704-525-8905	12/31/16
195793117	Crumbaugh, Cory W	M T C Consultants	5512 Jewel Dr	Waxhaw, NC 28173	704-361-0126	03/31/17
195130116	Crumbaugh, Marty E	Ed Davis Backflow	5512 Jewel Dr	Waxhaw, NC 28173	704-361-0126	12/31/16
195268117	Crumbaugh, Todd M	M T C Consultants Inc	5512 Jewel Dr	Waxhaw, NC 28173	704-361-2684	03/31/17
195286516	Daniels, Steve A	Performance Fire Protection	179 Gasoline Alley	Mooresville, NC 28117	704-201-2176	12/31/16
195109017	Danner, James M	Century Fire Protection	109 Commercial Blvd	Martinez, GA 30907	706-863-9374	06/30/17
195715117	Davis, Denver C	Diboco Fire Sprinklers	325 Jackson Loop Rd	Flat Rock, NC 28731	828-606-8591	12/31/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 34 of 38

Cert No.	Name	Employer	Address		Phone	Expires
195141217	Deal, Jonathan S	Unifour Fire & Safety	Po Box 9489	Hickory, NC 28603	828-328-6363	06/30/17
195798318	Delaplaine, Chip F	Cam-Ful Industries Inc	Po Box 279	Pineville, NC 28134	704-619-9481	12/31/18
195798719	Dennie, Brice T	All Fire Services	2100 W Front St Ste B	Statesville, NC 28677	704-928-7327	03/31/19
195168318	Denny, Matthew R	AML D C O Inc	4624 Dawnwood Dr	Charlotte, NC 28212	704-361-4370	06/30/18
195087817	Denny, Ray L	Amlco Inc	4624 Dawnwood Dr	Charlotte, NC 28212	704-426-7625	06/30/17
195716018	Depew, Lane R	Carolina Fire Protection Inc	4055 Hodges Chapel Rd	Dunn, NC 28334	910-892-1700	06/30/18
195286717	Desear, David R	Performance Fire Protection	179 Gasoline Alley	Mooresville, NC 28117	704-201-4170	06/30/17
195791116	Dever, Jason L	Rooterman Plumbers	200 Little McCall Rd	Guyton, GA 31312	912-236-3333	03/31/16
195711516	Draughon, Christopher R	Absolute Fire Control	149 Hicks Rd	Grover, NC 28073	704-622-0468	09/30/16
195794817	Duddleston, Mark D	T3-Fms	5714 Tipperary Dr	Denver, NC 28037	607-331-4600	09/30/17
195146617	Eller, Jack G	Fire Control Systems	565 Rom Eller Rd	Ferguson, NC 28624	336-213-8099	12/31/17
195791216	Ellis, Aaron L	B F P E	3300 Hwy 421 N	Wilmington, NC 28401	910-338-6025	06/30/16
195239716	Essic, Lindsey	Unifour Fire & Safety	Po Box 9489	Hickory, NC 28603	828-328-6363	09/30/16
195797018	Filiberti, Lawrence D	Wayne Automatic Fire Sprinklers	4370 Motorsport Dr	Concord, NC 28027	704-782-3032	06/30/18
195269117	Flowe, Michael D	Fire & Life Safety America	801 Biscayne Dr	Concord, NC 28027	704-886-5733	09/30/17
195235516	Fontana, Joe	Unifour Fire & Safety	Po Box 9489	Hickory, NC 28603	828-328-6363	03/31/16
195792416	Foxx, William C	Unifour Fire & Safety	1025 Tate Blvd Se	Hickory, NC 28681	828-320-3048	09/30/16
195798018	Freeman, John T	VSC Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-239-9075	09/30/18
195186117	Garmon, Thomas R	VSC Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-267-6851	09/30/17
195715017	Gibbons, Regis	Diboco Fire Sprinklers	325 Jackson Loop Rd	Flat Rock, NC 28731	828-290-2373	12/31/17
195287316	Gibson, Shean C	International Fire Protection Inc	6935 Oak Ridge Commerce Austell, GA 30168		770-745-4530	09/30/16
195106118	Glover, Eric W	Absolute Fire Control	215 Lawton Rd	Charlotte, NC 28216	704-333-7388	06/30/18
195205818	Goodman, Calvin L	Century Fire Protection	109 Commercial Blvd	Martinez, GA 30907	706-863-9374	09/30/18
195791816	Green, Eric R	International Fire Protection	2754 Marshall Dr	Tifton, GA 31793	229-388-8888	06/30/16
195220318	Hames, Timothy T	VSC Fire & Security Inc	14229 Luscombe Farm Rd	Charlotte, NC 28278	704-805-9700	12/31/18
195793617	Hamlin, Kevin A	James & James Environmental	Po Box 519	Mountain Home, NC 28758	828-697-0063	03/31/17
195794417	Hardy, Dustin C	Hardy Plumbing	559 Autumn Rd	Hephzibah, GA 30815	706-863-2110	06/30/17
195182717	Hatley, William G	Fire & Life Safety America	801 Biscayne Dr	Concord, NC 28027	704-722-7905	09/30/17
195135318	Hazelton, David	Wayne Automatic Fire Sprinkler	4370 Motorsports Dr	Concord, NC 28027	704-782-3032	06/30/18
195225817	Helms, Thomas H	Action Mechanical Contractors Inc	Po Box 7325	Charlotte, NC 28241	704-578-4450	06/30/17
195793517	Hensley, Robert G	James & James Environmental	3801 Asheville Hwy	Mountain Home, NC 28758	828-697-0063	03/31/17
195795317	Hernandez, Jenaro	Commercial Services	105 Ruth St	Cary, NC 27511	919-469-1672	12/31/17
195283017	Higdon, Ollie J	Precision Maintenance Inc	Po Box 3012	Evans, GA 30809	706-394-9891	06/30/17
195055418	Holmes, Jeff D	Eagle Fire Inc	570 Griffith Rd	Charlotte, NC 28217	843-441-0530	06/30/18
195117518	Hornbeak, Preston D	Virginia Fire & Security	8500 Danfield Dr	Kannapolis, NC 28081	704-805-9700	12/31/18
195263218	Hovestadt, Robert P	Roto Rooter	11440 Laurel View Dr	Charlotte, NC 28273	803-242-5482	12/31/18

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 35 of 38

Cert No.	Name	Employer	Address		Phone	Expires
195797818	Howell, Benjamin T	V S C Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	803-818-1343	09/30/18
195715918	Hudson, Eric D	Carolina Fire Protection Inc	4055 Hodges Chapel Rd	Dunn, NC 28334	910-892-1700	06/30/18
195715818	Hudson, Ronald C	Carolina Fire Protection Inc	4055 Hodges Chapel Rd	Dunn, NC 28334	910-892-1700	06/30/18
195797718	Huss, Joshua A	Unifour Fire & Safety	1025 Tate Blvd	Hickory, NC 28603	828-328-6363	09/30/18
195714017	Ingram, Julien Y	Performance Fire Protection	Po Box 4510	Mooresville, NC 28117	704-663-1664	12/31/17
195270116	Jackson, Willie E		114 Timber Ridge Dr	Raeford, NC 28376	910-813-0415	12/31/16
195255718	Jaime, Jeffeory D	Pye Barker Fire Safety	1013 Lynes Ave	Savannah, GA 31415	912-655-7858	03/31/18
195793417	James, Juanita R	James & James Environmental	Po Box 519	Mountain Home, NC 28758	828-697-0063	03/31/17
195007418	James, Toby L	Bill James & Son Inc	1225 New Savannah Rd	Augusta, GA 30901	706-724-2142	06/30/18
195795117	Jimenez, Juan C	Eagle Fire Inc	570 Griffith Rd	Charlotte, NC 28217	704-301-8272	12/31/17
195282418	Johnson, Donald L	Pioneer Utilities & Plumbing Inc	Po Box 893	Dallas, NC 28034	704-913-6984	12/31/18
195267418	Johnson, Edward B	V S C Fire & Security	136 Shinnville Rd	Mooresville, NC 28115	704-746-5152	12/31/18
195798819	Johnston, Ray T	Sylvester & Cockrum Inc	6000 Gun Club Rd	Winston Salem, NC 27103	336-766-3430	03/31/19
195711418	Jones, Christopher M	Absolute Fire Control	3025 Wilson St	Belmont, NC 28012	704-361-0230	06/30/18
195175418	Jones, Christopher W	Allegiance Fire Protection Llc	6230 Riverwoods Dr Apt 202	Wilmington, NC 28412	910-232-1043	06/30/18
195222517	Jones, Steven D	V S C Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-506-8882	09/30/17
195128216	Kepley, David A	Carolina Fire Control Inc	Po Box 1090	Concord, NC 28026	704-309-4846	09/30/16
195032117	Kessinger, Donovan J JR	B F P Technicians Inc	Po Box 786	Grayson, GA 30017	770-822-1514	03/31/17
195796018	Kessler, Marianne M	Rainmaker Irrigation	10417 Callicutt Springs Ct	Huntersville, NC 28078	704-896-6200	03/31/18
195250517	Lambeth, Ricky D	I P I Fire Protection	13504 S Point Blvd Ste M	Charlotte, NC 28273	336-918-5980	12/31/17
195796218	Lang, Roger T	B F P E	3300 Hwy 421 N	Wilmington, NC 28401	910-762-5418	03/31/18
195176716	Lawrence, Jon E	Sunland Fire Protection Inc	6420-B Windmill Way	Wilmington, NC 28405	910-794-9101	03/31/16
195796918	Laws, Steven R	All Fire Services Llc	Po Box 6574	Statesville, NC 28687	704-881-6586	06/30/18
195793016	Lee, Hubert H		Po Box 306	Berea, OH 44017		12/31/16
195205316	Lockhart, Eric A	Plumbing & Mechanical Services Inc	Po Box 323	Dobson, NC 27017	336-374-4056	12/31/16
195270717	Logan, William T	William T Logan Backflow Specialist	7870 Old Louisville Rd	Soperton, GA 30457	912-682-4714	06/30/17
195031016	Maahs, Joe D	Earl L Babbitt	1128 Ellis St	Augusta, GA 30901	803-640-2478	06/30/16
195798218	Mahon, Scott R	Precision Plumbing	1400 Industrial Dr	Matthews, NC 28105	704-591-7125	12/31/18
195286217	Maultsby, John A II	Quality Sprinkler Company	10301 Old Concord Rd	Charlotte, NC 28213	704-549-8220	12/31/17
195286118	Maultsby, John A SR	Quality Sprinkler Company	10301 Old Concord Rd	Charlotte, NC 28213	704-549-8220	06/30/18
195796618	Maxwell, Jordan O	Earl L Babbitt Plumbing	1128 Ellis St	Augusta, GA 30901	706-722-3591	06/30/18
195796518	Maxwell, Ronald K	Earl L Babbitt Plumbing	1128 Ellis St	Augusta, GA 30901	706-722-3591	06/30/18
195282618	Mayes, Francis R	V S C Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-805-9700	03/31/18
195248017	Mcglamery, Zachary A	Fire Control Systems	210 Mt Pleasant Rd	Ferguson, NC 28624	336-213-8097	09/30/17
195792616	Merritt, Mac	Joe Boxers Backflow Testing	1607 Sassafras Hill St	Durham, NC 27712	919-632-3080	12/31/16
195796418	Messer, Ricky A	Fire Control Systems	11515 Reames Rd	Charlotte, NC 28269	704-770-7392	06/30/18

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 36 of 38

Cert No.	Name	Employer	Address		Phone	Expires
195713717	Miller, Darin A	Precision Plumbing	1400 Industrial Dr	Matthews, NC 28105	704-849-7810	06/30/17
195151118	Mills, Stephen D	Eagle Fire Inc	570 Griffith Rd	Charlotte, NC 28217	704-661-8516	12/31/18
195241916	Mills, William R	International Fire Protection Inc	6935 Oak Ridge Commerce	Austell, GA 30168	770-745-4530	09/30/16
195795517	Minnick, Zachary E	Diboco Fire Sprinklers	325 Jackson Loop Rd	Flat Rock, NC 28731	828-696-3400	12/31/17
195203318	Minton, Doug A	Unifour Fire & Safety	1025 Tate Blvd	Hickory, NC 28603	828-328-6363	09/30/18
195715217	Mitchell, Andrew D	Quality Sprinkler Company	10301 Old Concord Rd	Charlotte, NC 28213	704-549-8220	12/31/17
195795417	Moore, Jesse C	Diboco Fire Sprinklers	325 Jackson Loop Rd	Flat Rock, NC 28731	828-696-3400	12/31/17
195250917	Morrison, Kevin M	I P I Fire Protection	13504 S Point Blvd Ste M	Charlotte, NC 28273	321-848-3599	12/31/17
195287117	Morrow, Robert	B V S Systems Inc	6004 Cougar Ln	Charlotte, NC 28269	704-896-9989	12/31/17
195044818	Oates, David T	John J Oates Plumbing Company	1032 Gum Branch Rd	Charlotte, NC 28214	704-392-4248	09/30/18
195256718	Ollis, Matthew L	Carolina Fire Control Inc	Po Box 1090	Concord, NC 28026	704-784-4218	06/30/18
195797618	Outlaw, Joseph W	Unifour Fire & Safety	1209 Old North Rd	Lenoir, NC 28645	828-855-4747	09/30/18
195222717	Page, Kenneth C	V S C Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-805-9700	09/30/17
195712016	Parker, James B	Parker & Associates	705 Laurel Ln	Gastonia, NC 28054	704-747-4329	09/30/16
195241716	Parker, James R	International Fire Protection Inc	6935 Oak Ridge Commerce	Austell, GA 30168	770-745-4530	09/30/16
195184117	Parks, Daniel J III	Unifour Fire & Safety	Po Box 9489	Hickory, NC 28603	828-851-4656	09/30/17
195795017	Peters, Bryan K	Summit Fire Protection	575 Minnehaha Ave W	Saint Paul, MN 55103	618-889-6842	12/31/17
195251617	Powell, Robert A	Wise Services Inc	1104 Windsong Cir	Augusta, GA 30907	706-284-7376	12/31/17
195792316	Pressley, Brandon L	I P I Fire Protection	13504 S Point Blvd Ste M	Charlotte, NC 28273	704-588-1100	09/30/16
195714217	Raffaldt, Timothy S	Fire & Life Safety America	801 Biscayne Dr	Concord, NC 28027	704-791-6257	09/30/17
195792916	Ramirez, Zeke R	Liberty Fire Protection Inc	130 Division Dr	Leland, NC 28451	910-289-5400	12/31/16
195713016	Raynor, Bradley W	Liberty Fire Protection Inc	130 Division Dr	Leland, NC 28451	910-279-5449	12/31/16
195135517	Richards, Scott	Wayne Automatic Fire Sprinkler	4370 Motorsport Dr	Concord, NC 28027	704-400-0923	09/30/17
195798518	Roach, Charles M	Eagle Fire Inc	570 Griffith Rd	Charlotte, NC 28217	704-302-3945	12/31/18
195213516	Rogers, Brian A	Hardy Welding & Piping Services	Po Box 58	Appling, GA 30802	706-541-9192	06/30/16
195798619	Rosanna, Timothy G	All Fire Service	2100 W Front St	Statesville, NC 28677	704-880-3478	03/31/19
195285918	Rosia, William C	Eagle Fire Inc	570 Griffith Rd	Charlotte, NC 28217	704-527-9111	06/30/18
195287416	Rouse, Dennis E	B F P E International	3300 Hwy 421 N	Wilmington, NC 28401	910-443-9256	03/31/16
195797218	Russell, Devin L	Wayne Automatic Fire Sprinkler Inc	4370 Motorsport Dr	Concord, NC 28027	704-782-3032	06/30/18
195714917	Russell, James T	All Fire Services Llc	2100 W Front St Ste B	Statesville, NC 28677	704-928-7367	12/31/17
195791716	Salter, Donald L	International Fire Protection	2754 Marshall Dr	Tifton, GA 31793	912-655-5607	06/30/16
195714718	Seastedt, Joshua R	Makson Fire Protection Inc	434 Calhoun St	Salisbury, NC 28144	704-202-1593	03/31/18
195189417	Setzer, Jamie A	All Fire Services Llc	2100 W Front St Ste B	Statesville, NC 28677	704-838-1011	12/31/17
195251517	Shepherd, Felix	Wise Service Inc	1919 Lionel St	Augusta, GA 30906	706-825-3046	12/31/17
195200618	Shytle, Michael R	Fire Control Systems	11515 Reames Rd	Charlotte, NC 28269	704-576-0468	06/30/18
195794017	Shytle, Zachary M	Fire Control Systems	1143 Commercial Ave	Charlotte, NC 28205	800-237-9701	06/30/17

S.C. Department of Health and Environmental Control
 Inspectors and Testers of Backflow Prevention Equipment
 Certified Testers, General

02/04/16
 Page 37 of 38

Cert No.	Name	Employer	Address		Phone	Expires
195714517	Sims, Adam L	Unifour Fire & Safety	Po Box 9489	Hickory, NC 28603	828-328-6363	09/30/17
195269818	Skinner, William H	Unifour Fire & Safety	Po Box 9489	Hickory, NC 28603	828-328-6363	03/31/18
195797418	Small, Joseph H JR	Stanley Environmental Solutions	131 Mariposa Rd	Stanley, NC 28164	704-263-8186	06/30/18
195086418	Smith, John P	Smith Brothers Mechanical	Po Box 2801	Augusta, GA 30914	706-733-9473	12/31/18
195715317	Stapleton, Charles E	H E R C Enterprises Inc	4779 Rocky River Rd	Concord, NC 28027	704-791-5244	12/31/17
195795617	Stave, David J	Diboco Fire Sprinklers	325 Jackson Loop Rd	Flat Rock, NC 28731	828-696-3400	12/31/17
195798118	Sutton, Anthony D	V S C Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-363-2758	09/30/18
195226318	Sutton, Jeremy W	Simplex Grinnell	9826 Southern Pine Blvd	Charlotte, NC 28273	704-883-4204	03/31/18
195111318	Swink, Robert Q	Elite Fire Control Inc	Po Box 1573	Salisbury, NC 28145	704-633-1644	03/31/18
195794717	Thomason, Robert D	Annual Backflow Company	2021 Bentley Dr	Stone Mountain, GA 30087	770-871-5446	09/30/17
195794517	Tucker, Joshua B	V S C Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-361-9045	09/30/17
195716418	Uhrin, John	Blackstone Irrigation	4364 Triple Crown Dr	Concord, NC 28027	980-521-7374	09/30/18
195796818	Ventry, Nicholas R	M S I	Po Box 480550	Charlotte, NC 28269	704-517-7132	06/30/18
195791916	Walden, Cody	Fire & Life Safety	9782 Quail Run Rd	Locust, NC 28097	704-507-5270	09/30/16
195158416	Walker, Robert D	Wayne Automatic Fire Sprinkler	4370 Motorsport Dr	Concord, NC 28027	704-201-7350	09/30/16
195239416	Ward, William T	Fire Control Systems	1143 Commercial Ave	Charlotte, NC 28205	704-377-3022	09/30/16
195090218	Watson, Richard T	Smith Brothers Mechanical	1711 N Leg Ct	Augusta, GA 30909	706-733-9473	12/31/18
195126817	Webb, William C	Eagle Fire Inc	540 Griffith Rd	Charlotte, NC 28217	704-527-9111	09/30/17
195206118	Westenberger, Robert	Century Fire Protection	109 Commercial Blvd	Martinez, GA 30907	706-863-9374	09/30/18
195715618	Williams, Mark A	V S C Fire & Security	3109 Westinghouse Blvd	Charlotte, NC 28273	704-805-9700	03/31/18
195287718	Williams, Melvin Z	Best Rate Backflow	3919 Amarillo Dr	Concord, NC 28027	980-622-9016	12/31/18
195237116	Wright, Christopher B	Eagle Fire Inc	570 Griffith Rd	Charlotte, NC 28217	704-527-9111	03/31/16
195796718	Zehnder, Ronald H	Rooterman Plumber	208 Magnolia St	Guyton, GA 31312	912-236-3333	06/30/18
195131516	Zensen, John S	Pye Barker Fire & Safety	153 Whisperwood Dr	Hendersonville, NC 28791	843-300-5684	03/31/16

Total: 167

Grand total: 1154

SECTION 4: TESTING NOTIFICATION LETTER AND REPORT FORM

A written notification of the required inspection date will be sent to each customer annually. Following is a template for the letter as well as a copy of the form showing the required testing information.

(Date)

(Customer's Name & Address)

Dear Customer:

LRWS owns and operates the water systems in the Towns of Hampton, Varnville, Brunson, Gifford and Yemassee. In order to continue to maintain the quality of our water supply at the highest level possible, LRWS has established a Cross Connection Control Program, which can be found on our website at www.lowcountrywater.com

Our records indicate that you have a backflow device that requires annual testing per State Primary Drinking Water Regulation, R61-58.7(F)7. We are requesting that all backflow device test reports be completed this year by _____. Please note the following:

- A written notification of the required inspection date will be sent to each customer annually. If the inspection report is not received by the required date, the customer will be notified that failure to provide the report within 30 days will result in disconnection of services per our Water and Sewer Use Regulations.
- Inspection and testing will be conducted at the expense of the water user. It is your responsibility to schedule testing. A list of certified testers may be found at <http://www.scdhec.gov/Environment/docs/backflow/bfgen.pdf>
- All test reports shall be submitted to LRWS by mail, fax or email at kari.foy@lowcountrywater.com

Please do not hesitate to contact us should you have any questions or concerns.

Sincerely,

Brian Burgess
General Manager

BACKFLOW DEVICE TEST REPORT FORM

Date: _____

Account Name/Business Name: _____

Account Address: _____

Account Number: _____ Meter Number: _____

Device Name: _____ Model Number: _____

Serial Number: _____ Size: _____

Device Location: _____

Tested by (PRINT): _____

	Check No. 1		Check No. 2		Air-Inlet Valve or Relief Valve	#1 Gate or Ball (Circle One)	#2 Gate or Ball (Circle One)
Test Before Repairs	(Mark One) Leaked _____ Closed Tight _____		(Mark One) Leaked _____ Closed Tight _____		Opened at _____ lbs. Differential Pressure	(Mark One) Leaked _____ Closed Tight _____	
	Diff Press		Diff Press			(Mark One) Leaked _____ Closed Tight _____	(Mark One) Leaked _____ Closed Tight _____
Repairs and New Materials							
Test After Repairs	(Mark One) Leaked _____ Closed Tight _____		(Mark One) Leaked _____ Closed Tight _____		Opened at _____ lbs. Differential Pressure	(Mark One) Leaked _____ Closed Tight _____	
	Diff Press		Diff Press			(Mark One) Leaked _____ Closed Tight _____	(Mark One) Leaked _____ Closed Tight _____

Above data certified to be correct.

Tester Signature: _____ Certification Number: _____

Company Name: _____ Company Telephone Number: _____

Category: _____ General _____ Limited _____ Inspector Tester

Method of Testing: _____ Test Kit Used: _____

Comments: _____

SECTION 5: INVENTORY OF LRWS TESTABLE DEVICES and TEST RESULTS

An inventory of all testable backflow prevention assemblies will be maintained as part of the Cross Connection Control program. The inventory will include the customer name, address, device manufacturer, model number, serial number, description of location on the property, most recent test date, test method, tester name and certification number, and results of the most recent test. This inventory will be reviewed and updated annually upon receiving test results.

LRWS is to be provided a written report of the inspection and testing results for all assemblies tested within the LRWS system. Copies of certified test results will be kept on file as part of the Cross Connection Control Program.

This section is organized by individual water system.

SECTION 6: RESIDENTIAL LAWN IRRIGATION SYSTEMS

A connection between LRWS and a low hazard residential irrigation system with no chemical addition will be protected by a residential dual check valve. Dual check valves associated with low hazard residential irrigation systems do not need yearly inspections. These devices will be the responsibility of LRWS and will be changed out when meters are changed out.

SECTION 7 – STATE PRIMARY DRINKING WATER REGULATIONS FOR CROSS CONNECTION CONTROL

**STATE PRIMARY DRINKING WATER REGULATIONS
AS AMENDED APRIL 29, 2005
R.61-58.7(F)**

F. Cross Connection Control

- (1) General
 - (a) All public water systems shall initiate and maintain a viable cross connection control program. Such a program shall consist of:
 - (i) Locating and eliminating unprotected cross connections.
 - (ii) Maintaining records pertaining to the location of existing backflow prevention assemblies, type and size of each assembly and annual test results.
 - (b) No person shall install, permit to be installed or maintain any cross connection between a public water system and any other non-public water system, sewer or a line from any container of liquids or other substances, unless an approved backflow prevention device or assembly is installed between the public water system and the source of contamination.
- (2) Low Hazard Cross Connections

A connection between an approved public water system and another water source not hazardous to health but not meeting the standards of the approved public water system and not cross-connected within its system with a potentially dangerous substance shall be considered a low hazard category cross connection. At a minimum, an approved Double Check Valve Assembly or Pressure Vacuum Breaker must be installed on a low hazard cross connection except as provided for in section 3 below.
- (3) Residential Lawn Irrigation Systems
 - (a) Low hazard residential lawn irrigation systems - Each public water system which has low hazard residential irrigation systems directly or indirectly connected to their public water system must have a written low hazard residential lawn irrigation system cross connection control policy. This policy must be documented in writing and must be approved by the governing body of the public water system. The policy must specify the minimum acceptable device for low hazard residential lawn sprinkler systems. The minimum acceptable device for low hazard residential lawn sprinkler systems is a residential dual check. If a water system specifies another backflow prevention assembly as the minimum acceptable protection for these cross connections, the policy must be approved by the governing body of the public water system with due opportunity being provided for public comment and participation. The written policy must:
 - (i) Identify the type of backflow prevention device or assembly that is required to be installed on low hazard residential lawn irrigation system connections.
 - (ii) Establish a schedule for the required testing of double check valve

assemblies, or other testable assembly, if testable assemblies are designated by the policy as minimum acceptable protection for low hazard residential lawn irrigation systems. The minimum testing frequency must be specified in the policy and appropriate records must be maintained to verify compliance with the established testing requirements.

(iii) Establish a schedule for the required change out of residential dual checks if these are the devices designated by the policy as minimum acceptable protection for low hazard residential lawn irrigation systems. The minimum change out frequency must be specified in the policy and appropriate records must be maintained to verify compliance with the established change out requirements.

(b) High hazard residential lawn irrigation systems – Any residential lawn irrigation system that includes chemical addition, or is also connected to another water source which is not an approved public water system, shall be considered a high hazard cross connection and must meet the requirements of paragraph (4) below.

(4) High Hazard Cross Connections

(a) A connection between an approved public water system and a service or other water system which has or may have any material in the water dangerous to health, or connected to any material dangerous to health, that is or may be handled under pressure, or subject to negative pressure, shall be considered a high hazard category cross connection. Protection shall be by air gap separation or an approved reduced pressure principle backflow prevention assembly.

(b) Reduced pressure principle backflow prevention assemblies shall not be installed in any location subject to possible flooding. This includes pits or vaults which are not provided with a gravity drain to the ground's surface that is capable of exceeding the discharge rate of the relief valve.

(5) Fire Sprinkler Systems

Fire line sprinkler systems, except those in the high hazard category shall be protected by an approved double check valve assembly. High hazard fire sprinkler systems shall include, but not be limited to: antifreeze systems, foam systems, systems charged from or tied into ponds, lakes, streams, or any water source other than the approved public water supply. High hazard category fire sprinkler systems shall comply with the requirements of Paragraphs (4) above.

(6) Approved Devices and Assemblies

The Department shall prepare and publish a list of backflow prevention assemblies approved by the Department for use in S.C., and this list shall be updated at least once annually.

(7) Testing Requirements

When double check valve assemblies, pressure vacuum breakers, and/or reduced pressure principle backflow prevention assemblies are installed to protect a public water system against the possibility of backflow from a customer's water service, routine testing of the assemblies shall be performed by a certified tester.

- (a) Each assembly shall be tested by a certified tester after installation and before use by the customer. Except as specified in paragraph 3(a)(ii) above, each assembly shall be tested at least once annually by a certified tester.
- (b) The public water system is to receive a written report of the inspection and testing results for all assemblies tested within its distribution system. The report shall be submitted by the certified tester making the inspection and test.
- (c) All backflow prevention assemblies shall be tested immediately after repairs of any kind are made to the assembly.

(8) Backflow Prevention Tester Certification

There are four (4) types of certified testers of backflow prevention assemblies; General Tester, Limited Tester, Inspector Tester, and Manufacturer's Agent. The definition of each type of certified tester is specified in R.61-58(A).

- (a) Each certified tester's license shall expire three (3) years from the date of issue. In order to renew this certification for three (3) more years, the tester shall come before a designated person approved by the Department and shall successfully complete a written examination with a passing score of 70%, and perform the prescribed test on an approved reduced pressure principle backflow prevention assembly, double check valve assembly, and a pressure vacuum breaker using the tester's own differential pressure gauge. The gauge must be accurate within 2% of full scale or +/-0.3 pounds per square inch differential (PSID). Any gauge found to be inaccurate or malfunctioning will be required to be calibrated or repaired as needed to bring it into compliance before certification will be renewed.
- (b) Any applicant for certification who fails to properly perform the above prescribed tests will have his certification revoked immediately and will have to successfully complete the state sponsored backflow prevention training and certification course in order to become re-certified as a tester of backflow prevention assemblies in South Carolina.
- (c) A certified tester may have his tester's certification revoked due to incompetence or falsification of test results, as determined by the Department.
- (d) The Department shall reserve the right to charge or allow for the charge of a nominal fee for the administration of the recertification of testers. This fee shall not exceed fifty dollars (\$50.00).

(9) Installations of Pressure Vacuum Breakers

Where used, pressure vacuum breakers shall be installed at a minimum of 12" inches above the highest downstream piping and shall not be subject to backpressure.